

**HALONIX TECHNOLOGIES PRIVATE LIMITED**  
**(NABL CERTIFICATION NUMBER: TC-7634)**  
**PLOT-5, SECTOR-12, IIE, SIDCUL, HARIDWAR-249403**

**IP TEST CERTIFICATE**

**Date: 27/06/2019**

Product : 22W LED Pit Light Luminaires suitable for 110V, 50Hz, AC supply  
Product Code : HLPIT-04-22-CW-110VAC  
Brand Name : HALONIX  
Document Reference : IS 10322 / IEC 60598 & TDS

Sr. No.	Requirements		Observation	Verdict
1.	Resistance to Dust and Moisture	Clause 2 of IS:10322 (Part 4) shall apply Test for ingress of dust and Moisture <b>(IP67)</b>	No ingress of dust and no accumulation of water.	Pass
		Insulation Resistance Shall be $\geq 2M\Omega$ on application of 500V DC	>2 M $\Omega$ Satisfactory	Pass
		Electric strength test Shall withstood a voltage of 1.5KV for 1 Min	Satisfactory	Pass

**NOTE: The Pit Light as referred passed in IP Test.**

**For HALONIX TECHNOLOGIES PRIVATE LIMITED**



**Sanjay Sharma**

**Halonix Technologies Pvt. Ltd.**

**Registered Office:**  
B-31, Phase II, Noida,  
Distt. Gautam Budh Nagar, Uttar Pradesh - 201305  
**Tel:** +91 120 4756100 | **Fax:** +91 120 4756101

*Formerly known as Halonix Technologies Limited*

**Manufacturing Unit:**  
Plot No. 5, Sector-12, IIE, SIDCUL,  
Haridwar, Uttarakhand - 249403  
**Tel:** +91 9568152111 | **Fax:** +91 01334 230696

**E-Mail:** [customercare@halonix.co.in](mailto:customercare@halonix.co.in)  
**Website:** [www.halonix.co.in](http://www.halonix.co.in)