प्रकाश विभाग, नगर निगम गाजियाबाद। नियम व शर्ते

1- दरें केवल नगर निगम के विद्युत विभाग में पंजीकृत फर्मों द्वारा ही दी गई मान्य होगीं।

2- कार्य के लिए जमानत धनराशि का एफ.डी.आर. लगाना अनिवार्य है। जो लेखाधिकारी, नगर निगम गाजियाबाद के नाम पर बधंक होगा।

3- निविदादाता द्वारा दरें शब्दों व अंकों, दोनो में देनी होगी। इस बात का विशेष ध्यान रखा जाए कि कटिंग व

ओवराईटिंग न हो। अन्यथा की स्थिति निविदा मान्य नहीं होगी।

4- निविदादाता द्वारा निविदा के प्रत्येक पृष्ठ पर कम्पनी द्वारा अधिकृत सक्षम अधिकारी के पठनीय हस्ताक्षर होंगे। बिना हस्ताक्षर की निविदा मान्य नहीं होगी।

5- निविदादाता द्वारा दी गयी दरें निविदा के स्वीकार होने के पश्चात एक वर्ष तक वैध मानी जायेंगी। इस हेतु कम्पनी को नगर निगम से अनुबन्ध करना होगा।

6- आपूर्ति किये गये सामान की ओरिजनल होने की गारन्टी के प्रमाण हेतु कम्पनी का चालान प्रस्तुत करना होगा।

7- जमानत एवं धरोहर राशि के सम्बन्ध में कोई बैंक गारन्टी स्वीकार नहीं होगी।

8- सशर्त कोई भी निविदा मान्य नहीं होगी और न ही उस पर विचार किया जायेगा।

9- निविदा स्वीकार होने पर सम्बन्धित फर्म/ठेकेदार द्वारा गाजियाबाद नगर निगम के नियमानुसार लिखित अनुबन्ध करना होगा।

10- नगर आयुक्त महोदय, नगर निगम गाजाियाबाद को यह अधिकार होगा कि वे बिना कारण बताये किसी भी निविदा अथवा समस्त निविदाओं को निरस्त कर सकते हैं।

11- उक्त शर्तों के साथ नगर निगम ठेके की सामान्य शर्ते भी लागू होंगी।

12- किसी भी विवाद की स्थिति में नगर आयुक्त, नगर निगम गाजियाबाद का निर्णय अन्तिमं एवं उभय पक्षों को मान्य होगा।

13- नगर निगम प्रकाश विभाग में पंजीकृत फर्में ही ई-टैण्डरिंग में प्रतिभाग कर सकेंगी।

अवर अभियन्ता

াক্ষিত্র अधिशासी अभियन्ता (वि0यॉ0)

मैं /हम एतदाता घोषणा करता हूँ /करते है कि मैने /हमने निविदा की सभी शर्तो का भली भांति अध्ययन कर लिया गया है तथा मैं /हमे किसी भी प्रकार की जानकारी की आवश्यकता नहीं है तथा सभी शर्ते मुझे /हमे पूर्णतः मान्य है।

Contractor

GHAZIABAD MUNICIPAL CORPORATION TENDER NOTICE NO: 1264 Date :- 07-08-18 -निविदा सूचना सं0 : दिनांक :-TENDER SL. NO. - 2 TENDER COST 2000+360 (G.S.T) = 23602,00,000/-DATE OF CLOSING: 23-08-18 **EMD** कार्य समाप्ति की अवधि. कार्य का नाम:- नगर निगम सीमान्तर्गत विभिन्न स्थलो पर एल0ई0डी0 लाईट लगाने के कार्य हेत् वार्षिक निविदा। Work Discripetion :-Name of contractor: Rate S.N **Quantity Items** Rates Unit Rate G.S.T (%) G.S.T Amount Supply and Fixing of 90 Watt factory wired LED light fitting, having pressure di-cast aliminium housing .Complete LED light Fitting must be approved from Bueru Of Indian Standard -IS-10322(Part 5/Sectionn 3) 2012 and conforming IP-65/66/67 protection level follow LM -78/79 test report and approved in AAA category in PWD lucknow. LED fixture must have proper heat desipation working temprature 5-50 degree celcious, having SC protection, for electronic driver, Surge protection of 4 kthroughe surge protection device, driver efficiency more then 85%, CR>70, Driver must have 1 voltage regulation from 140-240 v, lumen out put of the LED module must be 110-Lum per Watt ,Each LED module must have optical lance for uniform distribution of light .These LED light Fixture will be installed on the 50mm dia-5-mm thickness A class GI pipe bracket bended on suitable angle ,fixed with 50-mm*6-mm iron pole clampe (2 set) with nuts and bolts. For connection of these LED lights 4 Mtr 40/76 flexible coper wire, 4-6 Mtr 2.5mm

1

must be approved from Bueru Of Indian Standard -IS-10322(Part 5/Sectionn 3) 2012 and conforming IP-65/66/67 protection level follow LM -78/79 test report and approved in AAA catagary in PWD lucknow. LED fixture must have proper heat desipation working temprature 5-50 degree celcious, having SC protection, for electronic driver, Surge protection of 4 kthroughe surge protection device, driver efficency more then 85%, CR>70, Driver must have voltage regulation from 140-240 v, lumen out put of the LED module must be 110-Lum per Watt ,Each LED module must have optical lance for uniform distribution of light .These LED light Fixture will be installed on the 50mm dia-5-mm thickness A class GI pipe bracket bended on suitable angle ,fixed with 50-mm*6-mm iron pole clampe (2 set) with nuts and bolts. For connection of these LED lights 4 Mtr 40/76 flexible coper wire, 4-6 Mtr 2.5mm strended 2 core -pvc insulated PVC sheathed aluminum cable with 16 Amp MCB in junction box fixed on pole clamp.

pressure di-cast aliminium housing .Complete LED light Fitting

follow LM -78/79 test report and approved in AAA catagary in PWD lucknow. LED fixture must have proper heat desipation

voltage regulation from 140-240 v, lumen out put of the LED

optical lance for uniform distribution of light .These LED light

iron pole clampe (2 set) with nuts and bolts. For connection of

16 Amp MCB in junction box fixed on pole clamp.

3

strended 2 core -pvc insulated PVC sheathed aluminum cable with

Supply and Fixing of 72 Watt factory wired LED light fitting, having pressure di-cast aliminium housing .Complete LED light Fitting

16 Amp MCB in junction box fixed on pole clamp.

Supply and Fixing of 50 Watt factory wired LED light fitting, having must be approved from Bueru Of Indian Standard -IS-10322(Part 5/Sectionn 3) 2012 and conforming IP-65/66/67 protection level working temprature 5-50 degree celcious, having SC protection, for electronic driver, Surge protection of 4 kthroughe surge protection device, driver efficency more then 85%, CR>70, Driver must have 1 module must be 110-Lum per Watt ,Each LED module must have Fixture will be installed on the 50mm dia-5-mm thickness A class GI pipe bracket bended on suitable angle ,fixed with 50-mm*6-mm these LED lights 4 Mtr 40/76 flexible coper wire, 4-6 Mtr 2.5mm strended 2 core -pvc insulated PVC sheathed aluminum cable with

> 0.00 NNG, Ghaziabad