

Bid Document

Bid Details	
Bid End Date/Time	14-10-2019 11:00:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Coal
Department Name	Materials Management
Organisation Name	Nlc
Office Name	Materials Management
Total Quantity	75
Item Category	LED Luminaire (for Flood Light)
MSE Exemption For Years Of Experience And Turnover	No
Startup Exemption For Years Of Experience And Turnover	No
Document required from seller	OEM Authorization Certificate
Bid to RA enabled	No

LED Luminaire (for Flood Light) (75 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	LED Luminaire conformity to IS:10322/Part 5/Section 5/2012 latest and IS: 16107 (Part 2/Sec 1):2012 latest	Yes	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	Types of LED Luminaire as per the IS:	Type B	*

	16107(Part-2/ Sec.-1)/2012		
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*
	LED Rating/System Wattage/Rated Power	150W	150W
	Luminaire System Efficacy (Lumen/watt)	>= 100 Lm/Watt	*
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP65	IP65
	Mounting brackets (included)	Adjustable	*
	Warranty for free replacement (in Years)	2	2
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	140 to 270 V olts AC at 50 Hz+/-2 Hz with auto cutt off at below 120V	*
	Automatic Higher Cut off voltage above 300 volt	Yes	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor at full load	≥ 0.95	*
	Driver Efficiency (in %age)	≥85	*
	Total Harmonics Distortion (in %age)	≤ 10	*
	"The total circuit power shall not be more than 110 percent of the value declared by the manufacturer"	Yes	*
OPTICAL	LED chip Efficacy	≥130 Lm/Watt	*
	Colour temperature (+/-500K)	6000K	*
	Working life for LED (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥70	*
	Beam Angle	≥120	*

	Optic lense materal (UV stabilised) (Write NA for without optic lense supply)	Poly carbonate lense	*
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Junction temperature	< 85 degC	*
	Operating temperature range	-20 deg C to +50 deg C	*
	Operating Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	Over Voltage protection	Yes	*
	Reverse polarity	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients (Internal)	>/=5KV	*
	The luminaire shall be protected against surges and transients of >/=10KV (External)	Yes	*
CONSTRUCTIONAL	The Luminaires casing/housing (single piece housing) shall be pressure die casted aluminium alloy with higher thermal conductivity	Yes	*
	The luminaire body must be corrosion resistant epoxy powder coated	Yes	*

All fastners must be of stainless steel	Yes	*
The entire housing (both LED section and driver section) shall be dust and water proof having IP 66 protection as per IS:10322 (Part 1):1982 latest	Yes	*
Extruded silicon loop gasket shall be provided in the lantern body to ensure a weather proof seal between the UV Glass cover and the metal housing to exclude the entry of the dust, water, insects etc.,	Yes	*
Luminaries light transparency should be of Toughened glass	Yes	*
Toughned transparent glass cover thickness	>/=4 mm	*
Toughned Glass shall not get discoloured shall not suffer degration due to heat and ageing within warranty period	Yes	*
Number of electronic control gear (power supplies)	2 Nos.	2 Nos.
Driver components shall be industrial grade or above	Yes	*
PCB shall be FR4 grade minimum 0.8 to 1.0 mm thick or more	Yes	*
The Luminaires works on single phase three wires system (Phase, Neutral and Earth)	Yes	*
Suitable connector shall be provided for LED connection between driver output and LED	Yes	*
Length of ISI marked three core wire (shall be provided along with	50 cm	*

MARKING	supply of material)		
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	"Manufactures Name and and brand on the aluminium die cast body	Engraved/Embossed	*
	Manufacturer's name, model number, serial number	Yes	*
	Date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
REPORTS AND CERTIFICATIONS	The operation characteristics voltage and power be marked inside of each LED luminaire unit	Yes	*
	LED Make	OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND	*
	System must have EMI/EMC compliance as applicable (Test reports shall be furnish on demand by buyer/consignee)	Yes	*
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government lab/NABL/ILAC accredited lab. Reports shall be furnish on demany by buyer (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
	LM 80 & TM 21 (Part of LM 80) (Ref. IS:16105:2012) Reports and Photo biological	Yes	*

	report for LED report from Central Government lab /NABL/ILAC accredited lab. Reports shall be furnish on demany by buyer (LM-80 report shall haveand the Pohoto Biological report of the LED Chip being used in the luminaire)		
	Availability of test Report from Central Government lab/NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-5/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes	*
	Seller has to furnish Type test report on demand by buyer/consignee	Yes	*
	DC or AC supplied electronic control gear for LED Module shall complpy as per IS:15885 (Part 2/Sec.13)	Yes	*
	LED Luminaire for Flood Light shall comply with Complusory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 5): 2012 as applicable on the date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	SRINIVASAN KALIYAPERUMAL	607807,PERMANENT CENTRAL STORES, NLC INDIA LIMITED, NEYVELI 607807	75	30

EMD Detail

--	--

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Buyer Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods
2. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of this Policy. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.
3. ISO 9001: The bidder must have ISO 9001 certification.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---