

### **25W LED HW STREET LIGHT**

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

25W Energy Efficient LED Street Light

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 11/05/2019

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Test Report**

Report Number: 05-11-2019 -003		05-11-2019
Product Description: 25W Energy Efficient LED Street Light		
Product Catalogue Reference: HLSLD-09H-25-CWL-R	Brand:	HALONIX
Construction:	•	•
Pressure die casted aluminum housing, Glass front visor, SMD LI	ED, Electronic driver etc.	
Test Details: Document		es/Standard:
<ul> <li>Light intensity distribution Measurement</li> <li>Total Lumen output Measurement</li> <li>Electrical Parameters Measurement</li> </ul>	<ul> <li>IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products"</li> <li>IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products"</li> <li>IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources"</li> </ul>	
Enclosures:		
Prepared By:	Approved By:	
Sanjay Sharma	Rajeev Chhabra	

### HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

**Photometric Test Report:** (As Per IES LM 79-08)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

**Total Measured Lumen:** 

**Light Intensity Distribution:** 

Approved By: Rajeev Chhabra

CCT:

#### **Electrical & Photometric Test Report**

<b>Sample ID:</b> 05-11-2019 -003				
Catalogue Reference:	HLSLD-09H-	HLSLD-09H-25-CWL-R		05-11-2019
Testing Agency:	HTPL Labora	HTPL Laboratory		HALONIX
Equipment Used:	EVERFINE B	EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe		
	Photomete	Photometer (Type: PMS – 50/80) with Power Meter		
Ambient Temperature:	25±2°C	Relative Humidity:	65%	
Test Voltage:	240V	Frequency:	50Hz	
Stabilization Time:	30Min	Total Operating Time:	1.30Hours	
	<u>'</u>	,	•	
Rated Performance Parameters	<b>:</b>			
Rated Wattage :	25W	Rated Input Current:	0.121A	
Nomical CCT :	5700K	Nominal CRI :	>70	
		•	•	
Measured Electrical Parameter	s:			
Supply Voltage:	240V	Input Current :	0.107A	
Frequency:	50Hz			
Total Power :	24.97W	Power Factor :	0.972	
	!	•	•	
Photometric Measurement Dat	a:			

2538.2lm 5821K Luminaries Efficacy:

Attached (Refer to Page No. 4) **Tested By:** Sanjay Sharma

CRI:

101.65lm/W

72.1

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Light intensity Distribution Diagram**



Catalogue Reference	HLSLD-09H-25-CWL-R	Sample ID	05-11-2019 -003