

HALONIX TECHNOLOGIES PRIVATE LIMITED

Regd Office:-

B-31, Noida Phase - II, Dist.-Gautam Budh Nagar, U.P, Pin-201305

TECHNICAL DATA SHEET

LED 36W HW Street Light

HLSLD-09-36-CWL-R

As per IS 10322 (Part-5/Sec-3) & IEC 60598-1

Product Description: Energy efficient 36W LED Street Light

Technical Specifications:

Main Housing / Heat Sink Material:

Front Cover:

Aluminium PDC

Clear toughened glass

Lens: Suitable high efficient secondary lens

LED: LM80 certified LED Lumen Maintenance: 50000 hours @ L70

Lumen Maintenance: 50000 hours @ L70
Control Gear: Isolated, Electronic, CC Driver


Internal Wiring: Insulated Cu wire


Hardwares: SS & MS Zinc plated and passivated

Ingress Protection: IP66
Impact Resistance: IK05

Operating Voltage Range: $140V^{\sim} 270V$ Operating Temperature: $-10^{\circ}C^{\sim} 50^{\circ}C$

GA Drawing:





All dimensions are in mm (Tolerance: ±5mm)

Electrical & Photometry Parameters:

| Rated Voltage | System | System | Power | System Lumen | CCT (As per ANSI) | CRI | THD | Driver |
|---------------|---------|---------|--------|--------------|-------------------|-----|------|------------|
| & Frequency | Wattage | Current | Factor | Efficacy | | | | Efficiency |
| 240V, 50Hz | 36W±10% | <174mA | ≥0.95 | ≥100lm/W | 5700K | ≥70 | ≤10% | ≥85% |

System Protections:

Open & Short circuit protection, reverse polarity protection, high voltage cut off at 300V±10V, surge protection of 5KV internal + 10KV SPD.

Application:

Street and road lighting, city squares, periphery lighting, complex boundry lighting, outdoor lighting, etc.

Mounting:

Pole mounting, suitable up to 40mm OD pipe bracket.

| Note: Due to continuous efforts in developing products, | · ' | MK/NK | Industrial Luminaire : |
|---|---------------|-------|-------------------------------|
| improvement M/s Halonix Technologies Pvt Ltd reserves the right to make changes in the design and data and withdraw the | Checked by : | AS | Cat. Ref. : HLSLD-09-36-CWL-R |
| luminaries without any prior notice. | Approved by : | RL | Document No : HWR-R-2019-KAL |

