

### **18W LED TUBE LIGHT CW**

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

**18W Energy Efficient LED Light** 

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 02/06/2019

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Test Report**

Report Number: 06-02-2	019 -001		Date:	06-02-2019
<b>Product Description:</b> 18W Energy Efficient LED Tube Light	t			
Product Catalogue Reference:	HLTLD-04-18-CW-HL2		Brand:	HALONIX
Aluminum housing, PC diffuser, etc.				
<ul> <li>Test Details:</li> <li>Light intensity distribution Measurement</li> <li>Total Lumen output Measurement</li> <li>Electrical Parameters Measurement</li> </ul>		<ul> <li>Document References/Standard:</li> <li>IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products"</li> <li>IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products"</li> <li>IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources"</li> </ul>		
Enclosures:				
Prepared By:		Aŗ	proved B	y:
Sanjay Sharma		Raj	eev Chhal	ora

## HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

**Total Power:** 

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Electrical & Photometric Test Report**

Photometric Test Report: (As Per	IES LM 79-08)			
Sample ID: 06-02-2019 -001				
Catalogue Reference:	HLTLD-04-1	HLTLD-04-18-CW-HL2		06-02-2019
Testing Agency:	HTPL Labor	HTPL Laboratory		HALONIX
Equipment Used:	EVERFINE B	EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe		
	Photomete	Photometer (Type: PMS – 50/80) with Power Meter		
	-			
Ambient Temperature:	25±2°C	Relative Humidity:	65%	
Test Voltage:	240V	Frequency:	50Hz	
Stabilization Time:	30Min	<b>Total Operating Time:</b>	1.30Hours	
Rated Performance Parameters:				
Rated Wattage :	18W	Rated Input Current:	0.092A	
Nomical CCT :	6500K	Nominal CRI:	>80	
Measured Electrical Parameters:				
Supply Voltage:	240V	Input Current :	0.077A	
Frequency:	50Hz			

Photometric Measurement Data:				
Total Measured Lumen :	2189.36lm	Luminaries Efficacy:	121.97lm/W	
CCT:	6484K	CRI:	82.2	
Light Intensity Distribution:		Attached (Refer to Page No. 4)		
Approved By: Rajeev Chhabra		Tested By: Sanjay Sharma		

**Power Factor:** 

0.971

17.95W

## HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India


Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Light intensity Distribution Diagram**



Catalogue Reference	HLTLD-04-18-CW-HL2	Sample ID	06-02-2019 -001