

### **40W LED POST TOP LIGHT CW**

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

**40W Energy Efficient LED Post Top Light** 

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 10/14/2019

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Test Report**

<b>Report Number:</b> 14-10-2019 -002	<b>Date:</b> 14	-10-2019
Product Description: 40W Energy Efficient LED Post Top Light		
Product Catalogue Reference: HLPT-04-40-CW-CAST	Brand: H	ALONIX
Construction:		
Die casted aluminum housing, Acrylic cover, SMD LED, Electroni	c driver etc.	
Test Details:	Document References/Stand	lard:
<ul> <li>Light intensity distribution Measurement</li> <li>Total Lumen output Measurement</li> <li>Electrical Parameters Measurement</li> </ul>	<ul> <li>IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products"</li> <li>IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products"</li> <li>IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources"</li> </ul>	
Enclosures:		
Prepared By:	Approved By:	
Sanjay Sharma	Rajeev Chhabra	

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Electrical & Photometric Test Report**

Photometric Test Report: (As Per I	ES LM 79-08)			
Sample ID: 14-10-2019 -002				
Catalogue Reference:	HLPT-04-40	HLPT-04-40-CW-CAST		14-10-2019
Testing Agency:	HTPL Labor	HTPL Laboratory		HALONIX
Equipment Used:	EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe Photometer (Type: PMS – 50/80) with Power Meter			
Ambient Temperature: 25+2°C Relative Humidity: 65%				

Ambient Temperature:	25±2°C	Relative Humidity:	65%
Test Voltage:	240V	Frequency:	50Hz
Stabilization Time:	30Min	<b>Total Operating Time:</b>	1.30Hours

Rated Performance Parameters:			
Rated Wattage :	40W	Rated Input Current:	0.193A
Nomical CCT :	5700K	Nominal CRI:	>70

Measured Electrical Parameters:			
Supply Voltage:	240V	Input Current :	0.169A
Frequency:	50Hz		
Total Power :	39.81W	Power Factor :	0.982

Photometric Measurement Data:			
Total Measured Lumen :	3646.99lm	Luminaries Efficacy:	91.61lm/W
CCT:	5781K	CRI:	73.2
Light Intensity Distribution:		Attached (Refer to Page No. 4)	
Approved By: Rajeev Chhabra		Tested By: Sanjay Sharma	

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India


Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Light intensity Distribution Diagram**



Catalogue Reference	HLPT-04-40-CW-CAST	Sample ID	14-10-2019 -002