

Annexure-1

S.No.	ATTRIBUTES	REQUIREMENT	VENDOR'S CONFIRMATION/ REMARKS
1	LUMINAIRE	Supply of Non Flameproof 125 W LED high bay light fitting	
2	Voltage	Operating voltage 140V to 277 V AC , 50Hz	
6	IP PROTECTION CLASS	Weather proof IP65 (or better) conforming to. IS:12063/1987 (IEC60529/1989)	
7	Cable entry	2 No's 3/4"ET threaded cable entry with 2 No's double compression nickel plated brass cable gland suitable for 3Cx2.5mm2 copper, PVC sheathed, insulated armored cable & 1 No. brass stopper plug	
8	TEMPERATURE CLASS	T-6	
9	GASKET	Endless ,moulded neoprene rubber	
10	EARTHING	1 No. Internal & Minimum 1 No's External with fixing screws/ bolts	
11	PAINTING	The housing shall be painted epoxy grey outside and white inside.	
12	TECHNICAL CATALOGUES	Vendor shall submit the complete technical details, GA Drawing and Catalogues along with the offer.	
13	FINISHING	EPOXY COATED, AS PER SHADE 632 OF IS-5.	
14	MOUNTING	Wall/Ceiling	
15	NAME PLATE	DETAILED NAME CUM WARNING INSCRIPTION	