

Bid Document

Bid Details	
Bid End Date/Time	06-11-2019 13:00:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Railways
Department Name	Na
Organisation Name	N/a
Office Name	Southern Railway
Total Quantity	2060
Item Category	LED Luminaire (For Road and Street Lights)
Average Turnover (Last 3 Years)	5 Lakh (s)
OEM Average Turnover (Last 3 Years)	10 Lakh (s)
Experience with Government Required	3 Year (s)
MSE Exemption For Years Of Experience And Turnover	No
Startup Exemption For Years Of Experience And Turnover	No
Document required from seller	Experience with Government,Annual Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover
Bid to RA enabled	Yes

Note:

1. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

LED Luminaire (For Road And Street Lights) (2060 pieces)

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	LED Luminaire conformity to IS:10322/Part 5/Section 3/2012 latest and IS: 16107 (Part 2/Sec 1):2012 latest	Yes	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	Types of LED Luminaire as per the IS: 16107(Part-2/ Sec.-1)/2012	Type B	*
	Types of LED Modules as per the IS:IS: 16103(Part-2)/2012	Type 3	*
	LED Rating (in Watts)/System Wattage/Rated Power	25W	25W
	Luminaire System Efficacy (Lumen/watt)	>= 100 Lm/Watt	*
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66	*
	Warranty for free replacement (in years)	2	2
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	90 to 300 Volts AC at 50 Hz+/-2	*
	Automatic Higher Cut off voltage above 300 volt	Yes	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor at full load	≥ 0.95	*
	Driver Efficiency (in %age) Upto 100W: ≥85%, Above 100W: >=90%	Yes	*
	Total Harmonics Distortion	≤ 10	*
	"The total circuit power shall not be more than	Yes	*

	110 percent of the value declared by the manufacturer (as per Cl. 8 of IS:16104:2012 lates)"		
OPTICAL	LED chip Efficacy	≥130 Lm/Watt	*
	Colour temperature	6000+/-500K	*
	Working life for LED (Minimum 50,000 burning hours as per LM-80 and LM 21 reports)	Yes	*
	Colour Rendering Index(CRI)	≥70	*
	LED Beam Angle	≥120	*
	Optic lense materal (UV stabilised)	Poly carbonate lense	*
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes	*
	Junctiojn / Soldering point temperature shall not exceed 85 deg.c as per LM 80 report	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Operating temperature range	-10 deg C to +50 deg C	-10 deg C to +50 deg C
	Operating Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	Over Voltage protection	Yes	*
	Reverse polarity	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M Ohm	*
	The luminaire shall be protected against	>/=5KV	*

	surges and transients (Internal)		
	The luminaire shall be protected against surges and transients of $\geq 10\text{KV}$ (External)	Yes	*
CONSTRUCTIONAL	The Luminaires casing/housing (single piece housing) shall be pressure die casted aluminium alloy with higher thermal conductivity	Yes	*
	The luminaire body must be corrosion resistant powder coated	Yes	*
	All fastners must be of stainless steel	Yes	*
	Protection of the entire housing (both LED section and driver section) as per IS:10322 (Part 1):1982 latest	IP66	*
	Extruded silicon loop gasket shall be provided in the lantern body to ensure a weather proof seal between the UV Glass cover and the metal housing to exclude the entry of the dust, water, insects etc.,	Yes	*
	Luminaries light transparency should be of Toughened glass	Yes	*
	Toughned transparent glass cover thickness	$\geq 4\text{ mm}$	*
	Toughned Glass shall not get discoloured shall not suffer degradation due to heat and ageing within warranty period	Yes	*
	Number of electronic control gear (power supplies)	1 No.	1 No.
	Light Source	SMD LED Chip as per LM 80/IS16106	*

	Driver components shall be industrial grade or above	Yes	*
	PCB shall be FR4 grade minimum 0.8 to 1.0 mm thick or more	Yes	*
	The Luminaires works on single phase three wires system (Phase, Neutral and Earth)	Yes	*
	Suitable connector shall be provided for LED connection between driver output and LED	Yes	*
	Length of ISI marked three core wire (shall be provided along with supply of material)	100 cm	100 cm
MARKING	"Manufactures Name and and brand on the aluminium die cast body "	Engraved/Embossed	*
	Manufacturer's name, model number, serial number	Yes	*
	Date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics voltage and power be marked inside of each LED luminaire unit	Yes	*
	Diameter of pole Luminiare suitable for: (upto 45W Pole OD: shall be 40mm), (>45W<120W Pole OD: Shall be 50 mm), (above 120W: OD shall be 60 mm for which luminiare is suitable	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX /	*

	EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND	
System must have EMI/EMC compliance as applicable (Test reports shall be furnish to the buyer / consignee on demand)	Yes	*
LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
LM 80 & TM 21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-80 report shall have the Pohoto Biological report of the LED Chip being used in the luminaire)	Yes	*
Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-3/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes	*
Seller shall furnish the Type test reports to the buyer / consignee on demand	Yes	*
DC or AC supplied electronic control gear for LED Module shall complpy as per IS:15885	Yes	*

	(Part 2/Sec.13)		
	LED Luminaire for road and street lighting shall comply with Compulsory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 3): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	K.Rajarajan	620001,Office of the Senior Divisional engineer Divisional Railway Managers Office Tiruchirapalli, TIRUCHIRAPALLI, 620001	2060	60

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Buyer Specific Additional Terms and Conditions

1. OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.
2. Past Performance Criteria: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (PROVING SUPPLY OF CUMULATIVE ORDER QUANTITY IN ANY ONE YEAR) to be submitted along with bid in support of quantity supplied in the relevant year. In case of bunch bids, the CATEGORY RELATED TO primary product having highest bid value should meet this criterion.
3. Scope of supply (Bid price to include all cost components) : Only supply of Goods
4. Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder

during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

5. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.
6. IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.
7. Procurement under this bid is reserved for purchase from Micro and Small Enterprises whose credentials are validated online through Udyog Aadhaar for that product category. If the bidder wants to avail the reservation benefit, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service.
8. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
9. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
10. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.
11. ISO 9001: The bidder must have ISO 9001 certification.
12. Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 15 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---