

TENDER BOOKLET

TECHNICAL BID

| | |
|-------------------|--|
| TENDER NO. | RFQ- 49382 |
| SECTION | EMD-III |
| SUBJECT | Supply of lighting materials & consumable items for EMD CCPP, Dhuvaran GBPS. |

GUJARAT STATE ELECTRICITY CORPORATION LTD
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: www.gsecl.in
CIN: U40100GJ1993SGC019988

| Sr. No. | Index |
|---------|---------------------------------------|
| 01 | Tender notice |
| 02 | Terms and conditions regarding tender |
| 03 | Technical bid |
| 04 | Details of bidder |
| 05 | Annexure-I |
| 06 | Annexure-II |
| 07 | Integrity pack |
| 08 | Price bid (separate) schedule – B |

| | |
|--------------|--|
| Name of Firm | |
|--------------|--|

TENDER NOTICE NO. RFQ-49382

ACE [Generation] DHUVARAN TPS invites tenders for the supply as mentioned below. **Interested** bidders shall have to be submitted **ON LINE** through www.nprocure.com & in physical form (The Tender will only be considered, if submitted in both physical and online) by the intending bidders on or before due date of submission as mentioned in the tender notice. Demand draft for Tender Fee with EMD & all the relevant documents as per requirements of the tender shall also be submitted in a single cover on or before due date of submission through RPAD / Speed Post only to **The Add.Chief Engineer [G], GSECL, Dhuvaran Gas Based Power Station, Tal: Khambhat, Dist: Anand** duly Superscripted "E-Tender", with Name of supply, Due date of Opening & E-Tender No / Tender ID on or before due date and time of submission. All such documents should be strictly submitted by RPAD / SPEED POST only, otherwise the offer will not be considered and no further communication in the matter will be entertained.

No tender shall be accepted/ opened in any case after due date and time of receipt of tender irrespective of delay due to postal services or any other reasons and that the GSECL shall not assume any responsibility for late receipt of the tender.

All bidders are requested to submit Price-bid on Line through www.nprocure.com only and not to submit the Price Bid in Physical form - **this is mandatory**.

If Price Bid is submitted in physical form, same will not be opened and only on Line submitted Price bid will be considered for evaluation.

| Name of Work | Estimated Cost in Rs | Tender Fees in Rs(Non-Refundable) | E.M.D (Rs.) | | Security Deposit | Time Limit |
|--|----------------------|-----------------------------------|-------------|--------------|-----------------------|------------|
| | | | For MSME | For Non MSME | | |
| Supply of lighting materials & consumable items for EMD CCPP, Dhuvaran GBPS. | 9,92,618.71 | 500.00 + 18% GST | 7500.00 | 7500.00 | 10% of Order End cost | 3 MONTH |

| | | |
|-----|---|---|
| (1) | Last date of Bid down loading up to 17.00 Hrs | As per Tender Notice and n-procure site |
| (2) | Last date for receipt of tender (in online) up to 17.00 Hrs | As per Tender Notice and n-procure site |
| (3) | Last date of Physical receipt of all the relevant documents up to 15:00 Hrs . By RPAD or Speed Post only | On or before Technical stage opening date |
| (4) | Date of Opening of Technical Bid in hard as well as online (For e-Tender) (In presence of willing bidders) At 15:30 Hrs if possible | On Technical stage opening date |
| (5) | Date of Opening of Price Bid At 15:30 Hrs (if possible) (In presence of Qualified bidders) | Will be intimated to technically qualified parties only. |
| (6) | Validity of Tender from the date of opening of Technical Bid | 120 Days |

01. All the relevant documents as per requirement of the Tender must also be submitted physically along with the Tender Fee and EMD in sealed cover so that the same is received in this office on OR before the due date and time. All such documents should be strictly submitted by RPAD/speed post only. Otherwise the offer will not be considered and no any further communication in the matter will be entertained.
02. If the quantity quoted differs in the any of the technical bid forms and in price bid forms, it is at the discretion of GSECL to consider the quoted quantity.
03. Any technical questions, information and clarifications that may be required pertaining to this tender enquiry should be referred to the ADDL. **Chief Engineer (Gen.) Gujarat State Electricity Corporation Ltd., Gas Based Power Station, DHUVARAN – 388 610 (Dist. ANAND).** GSECL reserve the rights to accept / reject any or all tenders without assigning any reasons thereof.

**Signature of Contractor with Place /
Date / Firm Seal / Stamp**

For, Gujarat State Electricity Corporation Ltd.

-----S/D-----
**Addl. Chief Engineer(Gen.)
GSECL, DGBPS.**

TERMS AND CONDITIONS REGARDING TENDER

| | |
|-----------|---|
| 01 | TENDER FEE |
| A | Tender Fee is COMPULSARY. No exemption from payment of tender fees is given to any party . |
| B | Tender Fee(non refundable) will be accepted by D.D. in favour of Gujarat State Electricity Corp. Ltd., payable at Bank of Baroda, Dhuvaran Branch only (Branch Code No. DHUVAR). Cheque are not accepted & Tenders submitted without tender fee will not be accepted. Also T. Fee/EMD can be paid through RTGS/NEFT. Bank Account details are given here under. |
| 02 | EARNEST MONEY DEPOSIT |
| A | EMD(refundable) is to be paid by D.D. in favour of Gujarat State Electricity Corporation Ltd. payable at Bank of Baroda, Dhuvaran DGBPS Branch only. Cheque are not accepted & Tenders submitted without EMD are liable for rejection. |
| B | The exemption in payment of EMD will be given to The Micro and Small Scale Industrial (manufacturing) Units registered under Small Scale Industries of Gujarat State and holding subsequent registration with CSPO / NSIC / DGS&D, Registration Certificates for the item under Tender will be eligible for exemption from payment of EMD on submission of notarized copies of their SSI (SSI/ MSME Part-II/Udyog Aadhaar Memorandum) & subsequent CSPO / NSIC / DGS&D Registration Certificates in EMD Cover. This benefit of exemption will not be admissible if they take part in the tender indirectly either through their dealers, agents, distributors or other intermediators . No exemption as well as relaxation shall be given to outside Gujarat based parties . |
| C | As per GOVT OF GUJARAT Finance Department.GR.No.:EMD/10/2018/18/DMO Date:16/04/2018 (A) Guarantees issued by following banks will be accepted as SD/EMD on permanent basis. 1. All Nationalized Banks including the public Sector Bank-1.IDBI Ltd. (B) Guarantees issued by following Banks will be accepted as SD/EMD for period up to march 31.2018, the validity cut-off date in GR is with respect to date of issue of Bank Guarantee irrespective of date of termination of Bank Guarantee. 1. Rajkot Nagarik Sahakari Bank Ltd,2. The Mehsana Urban Co-Operative Bank Ltd., 3.The Surat District Co-Op.Bank Ltd ,4. The Ahmedabad Mercantile Co-Op. Bank Ltd,5. Nutan Nagarik Sahakari Bank Ltd,6.The Kalupur Commercial Co-operative Bank Ltd.,7. Saurashtra Gramin Bank,8. Baroda Gujarat Gramin Bank,9. RBL Bank (The Ratnakar Bank Ltd.), 10.Axis Bank,11.Karur Vysya Bank,12.ICICI Bank 13.HDFC Bank 14.Kotak Mahindra Bank 15.IndusInd Bank,16.DCB Bank, 17.FEDERAL Bank,18.YES Bank |
| 03 | SECURITY DEPOSIT |
| A | Lowest party shall have to pay Security Deposit as, 5 % in case of Works & 10 % in case of Supply of order value before placement of order . If party fails to submit SD in prescribed time limit as mentioned in LOI, GSECL will take stern action against firm as per rules. |
| B | Small, Cottage and tiny industrial units of Gujarat State having the registrations numbers for production of goods and having the registration numbers from Govt. of Gujarat to submit Security Deposit and performance guarantee as under. The Micro and Small Scale Industrial (manufacturing) Units registered under Small Scale Industries of Gujarat State and holding subsequent registration with CSPO / NSIC / DGS&D Registration Certificates for the item under Tender shall submit Security Deposit & Performance Bank Guarantee as under on submission of attested copies of their SSI (SSI/ MSME Part-II/ Udyog Aadhaar Memorandum) & CSPO / NSIC / DGS&D Registration Certificates. This benefit of exemption will not be admissible if they take part in the tender indirectly either through their dealers, agents, distributors or other intermediators. (01) Wherever the Security Deposit and Performance Bank Guarantee rate of 5 % is stipulated, the same be considered at 3 % for Small, Cottage & tiny industrial units of Gujarat State. (02) Wherever the rate of Security Deposit & performance Bank Guarantee of 10 % is stipulated in |

| | |
|----|---|
| | the purchase policy, the same be considered as 4 % for Small, Cottage & tiny industrial units of Gujarat State. (03) Security Deposit and Performance Bank Guarantee shall not be insisted concurrently and therefore Security Deposit may be converted into Performance Bank Guarantee or once PBG is submitted, SD will be refunded |
| 04 | Technical Bid : The technical bid shall comprise of all the technical details of the stores / materials offered in accordance with the Corporation guaranteed technical particulars and conditions, etc. The Technical Bid shall be opened on Due Date as mentioned in tender Notice (If Possible), in the presence of those tenderers who wish to be present. If the Authorized Representative is likely to be present then he must submit the authorization letter of the representing company at the time of opening of Bids and this is compulsory. Only One authorized Representative shall be allowed. Please note that the required documents should be invariably submitted with tender copy. And tender without documents is liable to be ignored. |
| 05 | Price Bid (a) For Web Tender: The Price Bid must be submitted strictly as per Schedule-B and shall be submitted in the separate envelope (dully sealed) super scribed Price Bid with subject and shall be submitted simultaneously with the Technical Bid. The time and date for opening of the Price Bid shall be determined by the Corporation and shall be communicated to the tendering firms after technical bids are analyzed and the intimation will be sent only to the technically qualified tenderers. The “ Technical & Price Bids ” shall contain adequate cross reference wherever necessary to ensure clear and proper co-relation of the two bids without ambiguities whatsoever. Any technical questions information and clarifications that may be required pertaining to this Tender should be referred to The Chief Engineer, GSECL, TPS, DHUVARAN , who also reserves the right to reject any OR all tenders without assigning any reasons thereof. (b) For E-Tender: Bidders are requested to submit Price Bid (Schedule-B) on-line only and not to submit the price bid in physical form. This is mandatory. If price bid is submitted in physical form, same will not be opened and only on-line submitted price bid will be considered for evaluation. Further if the quantity quoted differs in the any of the technical bid forms and in price bid forms, it is discretion of Committee – GSECL to consider the quoted quantity. |
| 06 | The tender must be submitted in 04 (Four) Cover system . Cover 01: The technical bid and supporting documents. Cover 02: Price bid (Not required for online e- tender) Cover 03: EMD and Tender Fee Cover 04: All above three covers should be kept in 4 th cover duly super scribe the reference of payment of EMD & Tender Fee i.e. DD No. & Date for EMD - DD No. & Date for Tender Fee otherwise Bid will not be considered for opening. Tenderer should also certify as “ Unconditional Tender ” on tender cover it self. Conditional tenders are liable for rejection Bidder has to send tender by RPAD/Speed Post to The office of Chief Engineer (G), DHUVARAN ADM Building, GSECL Colony, DHUVARAN Gas Based Power Station, DHUVARAN, Dist: ANAND 388610 Gujarat, India on or before due date. In case of online e-Tender, It is mandatory to submit tender in online e-Tender as well as in physical form on or before due date and time. If tender submitted in only one way, it will not be considered for evaluation Corporation does not take any responsibility for postal delay on both ways and tenders received after due date and time will not be accepted by this office. |
| 07 | Tender fee & EMD should have to be submitted along with technical bid, if not found offer will be rejected |
| 08 | Gujarat State Electricity Corporation Ltd. reserves the right to accept/reject/Cancel any or all the offers/tenders, extend dates and / or re-advertise tender, and /or modify the Qty & process at any stage of the process without assigning any reason thereof |
| 09 | Arbitration clause. combined supply and works orders / tenders “ All questions, disputes or differences, whatsoever which may at any time arise between the parties to this contract in connection with the contract or any matter arising out of or in relation thereto, shall be referred to the Gujarat Public Works Contract Dispute Arbitration |

GUJARAT STATE ELECTRICITY CORPORATION LTD

Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand - 388610, Ph. 91 2698 242618

Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: www.gsecl.in

CIN: U40100GJ1993SGC019988

| | |
|----|---|
| | <p>Tribunal as per the provisions of the Gujarat Public works Contract Disputes Arbitration Tribunal Act, 1992". " All question, disputes or differences whatsoever which may at any time arise between the parties to this agreement touching the agreement or subject matter thereof, arising out or in relation there to and whether as to construction or otherwise shall be referred to the decision of the sole Arbitrator, appointed by the Chairman & MD, GSECL for that purpose, who shall be retired High Court Judge or a retired District and sessions Judge, and the decision of the said Arbitrator shall be final and binding upon the parties. Reference to the Arbitrator shall be governed by the provisions of the Arbitration and Conciliation Act, 1996 as amended from time to time and rules made there under. The Arbitration proceedings shall be conducted at HO GSECL, Vadodara or at such places as the Sole Arbitrator may be determined. The award of Sole Arbitrator shall be final and binding upon the parties".</p> |
| 10 | Any delay that may take place in supply or erection, testing and commissioning activities beyond contractual cut off date / stipulated period in the order shall be subjected to penalty (not liquidated damages) at the rate of ½% on goods not delivered per week or part thereof subject to a maximum of 10% on delayed portion. |
| 11 | <p>Payment</p> <p>A. For Supply: 80% Payment plus 100% taxes against receipt of material at site in good condition within 30 days & balance 20% against S.R. note within 45 days from date of inspection of materials at site in good condition, by crossed cheque on BOB DHUVARAN subject to advance stamped receipt received from you. Please send pre-receipted bills so as to effect prompt payment. Payment shall be made through RTGS/NEFT A/C payee cheque after receipt of advance stamp receipt. You are requested to provide the details in the format attached herewith for payment through RTGS/NEFT A/C payee cheque.</p> <p>B. For Works: if there is any work part in supply order, payment shall be made within 30 days from recording of bill.</p> |
| 12 | <p>Tenders duly filled must be accompanied by the following documents for tech. qualifying criteria Sealed rate tenders are invited from the reputed suppliers with sound engineering back ground, experience and financial capability, fulfilling qualifying requirement stated hereunder at DHUVARAN GBPS, Gujarat.</p> <ol style="list-style-type: none"> 1. List of recent orders (not more than 5 years old) for similar items executed by the party indicating the names of the organizations, order no and date, performance certificate for their supplied items 2. Satisfactory completion certificate of supply orders executed. 3. Any additional details regarding technical specifications or any deviation from the specification given by the Corporation in schedule-B, should be indicated clearly and separately in technical bid Annexure-II. 4. List of partners/ Directors with their permanent as well as present addresses phone no, Fax no and the name of immediate and authorized contact person. 5. GST registration no., date and issuing authority. 6. Bidder shall have to submit the PAN No for Income Tax & GST No. with documentary proof. |
| 13 | <p>PERFORMANCE GUARANTEE : Vendor will have to give Performance Guarantee equivalent to 10 % of the Order value against any manufacturing defect for the equipment / material supplied by him before claiming payment. This Performance Guarantee can be paid in cash or demand draft on Bank of Baroda, Dhuvaran in favour of Gujarat State Electricity Corporation Ltd. or in the form of an acceptable Bank Guarantee from 1. Rajkot Nagarik Sahakari Bank Ltd, 2. The Mehsana Urban Co-Operative Bank Ltd, 3. The Surat District Co-Op. Bank Ltd, 4. The Ahmedabad Mercantile Co-Op. Bank Ltd, 5. Nutan Nagarik Sahakari Bank Ltd, 6. The Kalupur Commercial Co-operative Bank Ltd, 7. Saurashtra Gramin Bank, 8. Baroda Gujarat Gramin Bank, 9. RBL Bank (The Ratnakar Bank Ltd.), 10. Axis Bank, 11. Karur Vysya Bank, 12. ICICI Bank 13. HDFC Bank 14. Kotak Mahindra Bank 15. IndusInd Bank, 16. DCB Bank, 17. FEDERAL Bank, 18. YES Bank as per the Standard Bank Guarantee form prescribed by the GSECL. This Performance Guarantee shall be valid up to completion of Guarantee / Warranty period i.e. 18 months from the last supply made by the vender or 12 months from the date of commissioning whichever is earlier.</p> |
| 14 | <p>GUARANTEE / WARARNTTEE: If the goods, store & equipment are found defective due to bad design / materials or poor workmanship, the same should be replaced by you free of charge, if reported within 18 months of their receipt at site or 12 months from the date of commissioning of goods equipments</p> |

GUJARAT STATE ELECTRICITY CORPORATION LTD
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: www.gsecl.in
CIN: U40100GJ1993SGC019988

| | |
|----|---|
| | whichever is earlier and submit certificate regarding this along with supply. |
| 15 | Party has to accept part order. |
| 16 | Party has to extend validity of offer for further , if required. |
| | Note: In case of conflict, the terms & conditions, specifications and requirement mentioned under Technical Bid will be considered. |

Signature of Contractor with Place / Date /
Firm Seal / Stamp

For, Gujarat State Electricity Corporation Ltd.

-----S/D-----
Addl. Chief Engineer(Gen.)
GSECL, DGBPS.

Real Time Gross Settlement (RTGS)/National Electronic funds transfer (NEFT) Mandate Form Detail.

1. Vendor/customer Name: **GUJARAT STATE ELECTRICITY CORPN.LTD**
2. Vendor/customer Code:
3. Vendor/customer Address: DHUVARAN TPS-388610.ANAND (GUJ)
4. Vendor/customer e-mail id: dtpscoa.gsecl@gebmail.com
5. **Particulars of bank account**
 - a) Name of Bank: **BANK OF BARODA**
 - b) Name of branch: **DHUVARAN**
 - c) Branch code:
 - d) Address :Market building, GSECL Colony, Dhuvaran:388 610
 - e) Telephone number: 02698 242530.
 - f) Type of account (current/saving etc) Current.
 - g) Account number: **030402-00000-121.**
 - h) RTGS IFSC code of the bank branch: **BARB0DHUVAR.** “0” Zero
 - i) NEEFT IFSC code of the bank branch: **BARB0DHUVAR.** “0” Zero
 - j) 9 digit MICR code :**388012502**

RTGS DETAILS FOR BIDDERS

1. NAME OF THE BENEFICIARY :
2. ACCOUNT No. :
3. NAME OF THE BANK :
4. NAME & ADDRESS OF THE BANK BRANCH :
5. TYPE OF ACCOUNT :
6. BANK CODE :
7. RTGS DETAILS :
8. IFSC CODE :
9. ATTACH SCAN COPY OF CANCELED CHEQUE :

Contact No:-

(1) Shri. K C CHUDHARY EX.ENGR(TECH)
Mobile No. 9925213026,
Mail : dtpstech.gsecl@gebmail.com

(2) Shri N.P. CHRISTIE DE(Tech)
Mobile No.9925210808
Mail: detch1dtps.gsecl@gebmail.com

ANNEXURE

Vendor must fill up below details & should place at the top of the Techno commercial Bid.

| | | |
|-----|---|----------------|
| 1. | PRICE (FIRM ONLY) | |
| 2. | FOR RATES OFFERED F.O.R.: Destination i.e. DHUVARAN TPS ONLY | |
| 3. | GST IN PERCENTAGE FOR EACH ITEMS Please Quote your GST Registration No. Date, it shall be specify in the % of taxes for individual item) | |
| 4. | PENALTY TRMS AGREE (Please Specify YES / NO) | |
| 5. | SECURITY DEPOSIT TERMS AGREE (Please Specify YES / NO) | |
| 6. | P.B.G. TERMS AGREED (Wherever applicable) (P.B.G. – Performance Bank Guarantee) (Please Specify YES / NO) | NOT APPLICABLE |
| 7. | GUARANTEE / WARARNTTEE TERMS AGREED | |
| 8. | DELIVRY TERMS (01 Months) | |
| 9. | PAYMENT TERMS AGREE (Please Specify YES / NO) 80% against receipt of material at site in good condition within 30 days & balance 20% within 45 days after inspection of material at site in good condition. (Advance payment condition will not be accepted) | |
| 10. | Validity (120 days from the date of opening of Technical Bid) | |
| 11. | ITEMS OFFERED | |

Signature of the Tenderer

Date :

Place :

TECHNICAL BID
(No Prices to be furnished in Tech. Bid)

Reference No. : DGBPS/TECH/EMD-III/62(19)/RFQ-49382

SUBJECT:- Supply of lighting materials & consumable items for EMD CCPP, Dhuvaran GBPS

| Sr. No. | Description of Material | HSNCODE | GST Rate With Cess If Any IN% | Qty. Reqd | Unit |
|---------|--|---------|-------------------------------------|-----------|---------|
| 1 | 50W LED FLOOD LIGHT WITH ALUMINUM BODY. | | | 33 | Number |
| 2 | LED LAMP 9 WATT, 230V | | | 34 | Number |
| 3 | 25W LED STREET LIGHT WITH PRESSURE DIE CAST HOUSING WITH TOUGHENED GLASS WITH IP65 PROTECTION | | | 56 | Numbers |
| 4 | 150 Watt LED High Bay light fitting | | | 52 | Numbers |
| 5 | 40 WATT LED LAMPS INDUSTRIAL WELL GLASSED LUMINARI ,SEPARATE CONTROL GEAR BOX WITH COMPLETE FITTING | | | 160 | Number |
| 6 | LED HIGH BAY LIGHT FITTING 90 WATT | | | 27 | Number |
| 7 | LED FLOOD LIGHT FIXTURE 150 WATT | | | 15 | Number |
| 8 | LOW BAY LED LIGHT 45 WATT, DOME TYPE FITTING. | | | 16 | Number |
| 9 | LED BULB, WATTAGE = 14W, BASE = E-27 (SCREW TYPE), LUMENS = 1400 LM, INPUT SUPPLY = 220-240 V AC, 50 HZ. | | | 131 | Number |
| 10 | LED BULB, WATTAGE = 7W, BASE = E-27 (SCREW TYPE), LUMENS = 700 LM, INPUT SUPPLY = 220-240 V AC, 50 HZ. | | | 31 | Number |
| 11 | SCREW TYPE COPPER CAP PORCELIN BATTON LAMP HOLDER 100/200W, 250V AC, HEAVY DUTY | | | 175 | Number |
| 12 | LED AVIATION OBSTRUCTION WARNING LIGHTS,(MEDIUM INTENSITY,TYPE-B),INTENSITY:1600 TO | | | 6 | Number |

GUJARAT STATE ELECTRICITY CORPORATION LTD
Dhuvaran Gas Based Power Station, Taluka-Khambhat, Dist-Anand – 388610, Ph. 91 2698 242618
Fax: 91-2698 242619/242409 e-mail: cedtps.gsecl@gebmil.com Website: www.gsecl.in
CIN: U40100GJ1993SGC019988

| | | | | | |
|----|--|--|--|-----|---------|
| | 2000CD.360 DEGREE ALL ROUND UNIFORM VISIBILITY,COLOR: RED, FLASHING:20TO60FLASH PER MINUTE,PROTECTION:WEATHER PROOF:IP 65,VOLTAGE: 230 V AC, +/- 15% | | | | |
| 13 | ENERGY SAVER CEILING FAN AS PER BEE STANDARD [IS:374] WITH 1200 MM SWEEP | | | 17 | Number |
| 14 | PVC ADHESIVE INSULATION TAPE ROLL | | | 300 | Number |
| 15 | HT PVC INSULATION TAPE SIZE 0.18 MM X25 MM X 65 MTR LENGTH | | | 4 | Roll |
| 16 | NYLONE ROPE 20 MM DIA | | | 60 | Meter |
| 17 | MANILA ROPE 3/4" | | | 60 | Meter |
| 18 | RUSTOLENE 500 ML/TIN | | | 50 | Number |
| 19 | RUST REMOVING SPRAY WD-40 IN AERSOLE PACKING OF HIGH PRESSURE VALVES . | | | 50 | Number |
| 20 | WIRE BRUSH SIZE 12" WITH WOODEN HANDLE | | | 5 | Number |
| 21 | 415V OFFLINE CONTACT CLEANER (700ML TIN) | | | 30 | Number |
| 22 | SINGLE PHASE AC 250/24VOLTS, 500VA TRANSFORMER MOUNTED IN SMC BOX WITH TWO 5/15 AMP PLUGS AND SWITCHES IN 24VOLT SIDE AND FUSE IN 250VOLT SIDE SUITABLE FOR MOUNTING ON STRUCTURE. | | | 2 | Numbers |
| 23 | HAND LAMP 100 WATT SCREW TYPE COMPLETE WITH GLASS,GUARD AND 10 METER TWO CORE,1.0 SqMM INSULATED FLEXIBLE WIRE | | | 20 | Numbers |
| 24 | COPPER FLEXIBLE WIRE 3 CX2.5 SqMM ,1.1 KV | | | 600 | Meter |
| 25 | FLEXIBLE PVC HARD PIPE SIZE 0.75" | | | 120 | Meter |

MATERIAL SPECIFICATIONS:

ITEM NO.01

Operating Voltage: 230 VAC, 50HZ (Range: 140V to 270V), Rated Wattage (Power Consumption): 50 Watt, Luminous Flux :> =4000 Lumen, Power factor >= 0.90, Total Harmonic Distortion < =15%, Life Span : >50000 Burning hours, Glass Type: Toughened Glass, Ingress protection: IP65/IP66, Luminaries Body: Aluminium Die Cast, Powder coated with mounting facility suitable for indoor/outdoor application area.
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.02

9 W LED Bulb (Cool white)
Light Source: SMD / COB LED., Life expectancy: Minimum 25000 Hrs. , Lighting wattage / Type: 9 W LED Bulb, CCT: 5700, 6500 deg K, ANSI , Minimum Luminous Flux: 800 Lumens
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.03

RATED WATTAGE: 25W, RATED VOLTAGE & FREQUENCY: 230V, 50HZ, I/p CURRENT: 0.12A, PF >0.95, OPERATING TEMP -20°C TO 50°C, VOLTAGE RANGE: 90V-300V, LUMENS: 2500lm, CRI >72, BEAM ANGLE: >179, MOUNTING POLE, BODY MATERIAL ALUMINUM, WORKING LIFE: 50,000 Hours, IP RATING: IP 65, COLOUR TEMPERATURE: CCT : 6500K, SUITABLE FOR POLE DIA: 30.00 MM,, Protection: Over voltage, short circuit protection, reverse polarity protection, SURGE PROTECTION,, THD <10%
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.04

Beam angle >=120 degree, LED efficiency at standard operating condition (lm per Watt) >= 100 lm/W, LED life span > 50000 hours, white colour LED, Colour temperature (K) = 5500-6500 K, Operating temperature = up to 50 deg C, Colour rendering index (CRI) >= 65, Housing. Aluminum die cast., Rated voltage 230 V AC, frequency 50Hz, Operating voltage (V): 140V to 270V, Input wattage (W): 150/ 160W, P .F. >= 0.90, THD (%) <= 15%, Ingress protection: -IP 65, Driver= constant current type, Driver efficiency >= 85%., Protection: Over voltage, short circuit protection, reverse polarity protection Surge protection >=5KV
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.05

LED efficiency at standard operating condition (lm per Watt) >= 90 lm/W, LED life span > 50000 hours, white colour LED, Colour temperature (K): 5500-6500K, Operating temperature= up to 50 deg C, Colour rendering index (CRI) >= 65, Housing: Aluminum die cast, Internal wiring: Teflon insulated, CU conductor, Hardware: SS / MS, zinc plated and passivated, Rated voltage 230 V AC, frequency = 50Hz, Operating voltage (V): 140V to 270V, Input wattage (W): 40W ? 2W, P .F. >= 0.90, THD (%) <= 15%, Ingress protection: IP 65, Driver = constant current type, Driver efficiency >= 85%., Protection: Over voltage, short circuit protection, reverse polarity protection Surge protection >=5KV, with mounting facility suitable for indoor/outdoor application area.
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.06

90 Watt LED Flood Light, 10000 lumen or more , Beam angle ≥ 120 degree, Rated voltage 230 V AC, frequency = 50Hz, Operating voltage range : 140V to 270V, Housing: Aluminum die cast, Internal wiring: Teflon insulated, CU conductor, Hardware: SS / MS, zinc plated and passivated, Operating temperature = up to 50 deg C, Colour rendering index (CRI) ≥ 65 , Input wattage (W): 90W ? 5W, P .F. ≥ 0.90 , THD (%) $\leq 15\%$, Ingress protection:-IP 65, Driver= constant current type, Driver efficiency $\geq 85\%$, Protection: Over voltage, short circuit protection, reverse polarity protection Surge protection $\geq 5KV$
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.07

150 Watt LED Flood Light, 17000 lumen or more, Operating Voltage: 230 VAC, 50HZ (Range: 140V to 270V), Rated Wattage (Power Consumption): 150 Watt, Power factor ≥ 0.90 , Total Harmonic Distortion $\leq 15\%$, Life Span : >50000 Burning hours, Glass Type: Toughened Glass, Ingress protection: IP65 or IP66, Luminaries Body: Aluminium Die Cast, Powder coated with mounting facility suitable for indoor/outdoor application area.
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.08

45 Watt LED Flood Light, 5000 lumen or more , Beam angle ≥ 120 degree, Rated voltage 230 V AC, frequency = 50Hz, Operating voltage range : 140V to 270V, Housing: Aluminum die cast, Internal wiring: Teflon insulated, CU conductor, Hardware: SS / MS, zinc plated and passivated, Operating temperature = up to 50 deg C, Colour rendering index (CRI) ≥ 65 , Input wattage (W): 45W ? 2W, P .F. ≥ 0.90 , THD (%) $\leq 15\%$, Ingress protection:-IP 65, Driver= constant current type, Driver efficiency $\geq 85\%$, Protection: Over voltage, short circuit protection, reverse polarity protection Surge protection $\geq 5KV$
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.09

14 Watt Screw type (E27 base) LED Lamp.
Wattage capacity = 14 watts, Minimum Lumens ≥ 1400 Lm, CCT- 6500 K, CRI ≥ 70 , Rated Voltage - 220-240V, Rated Frequency - 50 Hz, Beam angle - >120 , Rated life min. = 25000 Hrs, Ingress Protection $\geq IP 20$, Lamp Base - E27 (Screw Type),
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.10

7 Watt Screw type (E 27 base) LED Lamp.
Wattage capacity = 7 watts, Minimum Lumens ≥ 700 Lm, CCT- 6500 K, CRI ≥ 70 , Rated Voltage - 220-240V, Rated Frequency - 50 Hz, Beam angle - >120 , Rated life min. = 25000 Hrs, Ingress Protection $\geq IP 20$, Lamp Base - E27 (Screw Type)
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.11

Screw Type Copper Cap (E-27 base) Porcelain/plastic suitable for 100/125/200 Watt, 230V/250V AC lamp
MAKE: PHILIPS, BAJAJ, CROMPTON, SHAKTI, LITSUN, OREVA, OSRAM, Seoul, Eetamax, HAVELL'S, HALONIX, SURYA, GE, WIPRO, SAHASRA, SYSKA, EVEREADY, VENTURE

ITEM NO.12

LED AVIATION OBSTRUCTION WARNING LIGHTS,(MEDIUM INTENSITY,TYPE-B),INTENSITY:1600 TO 2000 Cd, 360 DEGREE ALL ROUND UNIFORM VISIBILITY,COLOR: RED, FLASHING:20TO60FLASH PER MINUTE,PROTECTION:WEATHER PROOF:IP 65,VOLTAGE: 230 V AC, +/- 15%, SHAPE: CYLINDRICAL DOME TYPE, SURFACE MOUNTING TYPE, EXPECTED LAMP LIFE: 50,000 HRS, POWER CONSUMPTION: 18-22 WATT, WEIGHT: 6 TO 7 KG, CONFORMING TO IS 10322 PART-5/SEC-3, DIRECTLY OPERATABLE 24X7 WITHOUT ANY CONTROLLER PANEL.
MAKE: AVIATION POWER SYSTEMS, INSTA POWER, GELTRONIX

ITEM NO.13

BEE 5 Star rated Ceiling Fan , Sweep : 1200 mm, Nominal input watts at maximum speed and at rated voltage : 50 Watts at 230 V., Air delivery at rated voltage : >210 cm, Service value : >= 4, Speed : 330 RPM, Down rod length : 300 mm, Colour : Brown or chocolate
MAKE: CROMPTON, USHA, ORIENT, HAVELLS, BAJAJ,KHAITAN

ITEM NO.14

PVC self adhesive insulation tape roll of the size 1.8cm width x 0.125mm thick x7.5mtr length in three different colours RED, YELLOW, BLUE each with Qty 100 nos.
MAKE: STILLGRIP,ANCHOR,BRITE,SUPERLEX,WONDER,TARTAN,EURO,MIRACLE

ITEM NO.15

HT PVC HEAVY DUTY INSULATION TAPE SIZE 0.18 MM X25 MM X 65 MTR LENGTH. COLOUR: BLACK, TEMP. 50 TO 260 DEGRE CELSIUS,
MAKE: PRS PERMACEL, ELECTRO WORLD, RAYCHEM, DENSON ,EURO,COSMOS ,TAP69,PLYSAFE

ITEM NO.16

NYLONE ROPE 20 MM DIA. MAKE: ANY STANDARD MAKE WITH GOOD QUALITY

ITEM NO.17

MANILA ROPE 3/4". MAKE: ANY STANDARD MAKE WITH GOOD QUALITY

ITEM NO.18

RUSTOLENE should be in standard pack of 500 ML/TIN. MAKE: PIDILITE

ITEM NO.19

Rust removing spray of WD-40 in aerosol packing of 400 ml bottle.

ITEM NO.20

WIRE BRUSH SIZE 12" WITH WOODEN HANDLE. MAKE: ANY STANDARD MAKE WITH GOOD QUALITY

ITEM NO.21

CFC free off line electrical contact cleaner h.d. Co2 : 700 ml. Spray can. Specific gravity : 0.7, flash point - (-17 deg. C), temperature range : 10- 32 deg. C, boiling point : 66 deg. C, k.b value : 31 k.b. QTY: 1 NUMBER = 1 TIN OF 700 ML, MAKE: STANVAC / MAXCHEM / BRIGHT/CRC/OKS/HEMLOC

ITEM NO.22

SINGLE PHASE AC 250/24VOLTS, 500VA TRANSFORMER MOUNTED IN SMC BOX WITH TWO 5/15 AMP PLUGS AND SWITCHES IN 24VOLT SIDE AND FUSE IN 250VOLT SIDE SUITABLE FOR MOUNTING ON STRUCTURE. MAKE: - GELCO, SIGMA, SHEPHERD TRANSFORMERS OR ANY OTHER ISI STANDARD MAKE.

ITEM NO.23

Hand lamp 24 VOLT AC, 100 WATT Screw type complete with glass , Guard and 10 Meter Two core 1.0 Sqmm Insulated flexible wire. MAKE: COMET,SHEPHERD,MIMIC,LARSEN

ITEM NO.24

Copper flexible wire 3 Core X 2.5 Sq MM, 1.1 KV Grade, Confirming to IS: 694. MAKE: JAINFLEX,POLYCAB,FINOLEX, RR KABEL, HAVELLS, ANCHOR, UNIVERSAL, ANGEL, OXCORD, RC BENTEX, KEI, RPG, V-GUARD

ITEM NO.25

FLEXIBLE PVC HARD PIPE SIZE 0.75" MAKE: ANY STANDARD MAKE WITH GOOD QUALITY

NOTES:

1. Warranty clause of GSECL: If the goods, store & equipment are found defective due to bad design /materials or poor workmanship, the same should be replaced by you free of charge, if reported within 18 months of their receipt at site or 12 months from the date of commissioning of goods equipments whichever is earlier and submit certificate regarding this along with supply.
2. Delivery period: 3 months from the date of LOI.
3. Date of manufacture of all items should not be older than three month

General terms and condition

- 1) If any additional deviation in specification please clearly mention in separate on this page of Technical Bid, dully signed. In no circumstances price should be quoted on this page
- 2) Party has to accept Payment terms as per GSECL norms
- 3) Bidder should give minimum required validity of offered rate for **120 days** from date of actual opening of Technical bid.
- 4) Party should invariably mentioned **GST, HSN code for each Items & PAN NUMBER** in their technical bid otherwise your offer will be ignored and price bid will not be opened.
- 5) Bidder should confirm delivery period as per GSECL requirement and same should be confirmed in Technical bid.
- 6) **The bidder must submit authorized dealer/distributorship certificate along with tech. bid OR he may produce purchase proof from OEM/Authorized dealer with bulk supply.**
- 7) Party shall have to quote their rates in case of Web tender in Schedule“B “of Price bid and incase of E-tender shall have to submit the rate online only. The details of applicable GST, taxes/duties, service charges, packing & forwarding charges, freight, and insurance, F.O.R. etc. shall be indicated clearly in Price Bid.
- 8) Bidder should keep their commercial terms and conditions similar in both technical Bids as well as in price Bid. They should not differ in any of the bid otherwise offer will be ignored. Only prices should be submitted along with only price Bid and not with the Technical bid.
- 9) Non complying of the above condition of the tender liable to be rejected.
- 10) GSECL reserves the right to prefer the overall lowest party if deem fit.
- 11) Supplier shall have to submit all the necessary documents like material Test certificate, other required test certificates, guarantee certificate, invoice etc along with supply as per the order terms. Without relevant required documents, further process of payment will not be initiated.
- 12) Supplier will not insist ‘C’ form along with the payment. However ‘C’ form will be issued directly to your office after completion of respective financial quarterly on receipt of demand note from you covering all the transaction during every month. Please note that no ‘C’ form will be issued if current month invoice is not submitted along with supply of material & no additional tax will be paid by GSECL.
- 13) Repeat order: GSECL reserves right for the placement of repeat order @ 25% of the order quantity / value within 4 [Four] months from the date of order .
- 14) Sample shall be submitted with technical bid or deputed your representatives with quoted materials sample after opening of technical bid.
- 15) Company Technical brochures shall be submitted with technical bid.

“I/we hereby have read the above documents and agree for the Conditions vide above documents and accordingly submitted my/our offer.”

**Signature of Contractor with Place /
Date / Firm Seal / Stamp**

For, Gujarat State Electricity Corporation Ltd.

-----S/D-----
**Addl. Chief Engineer(Gen.)
GSECL, DGBPS.**

DETAILS OF BIDDER

| | | |
|-----|--|---|
| 01. | Name of Firm & Contact Person | |
| 02. | Full Postal Address | |
| | Phone/Fax No. | |
| | Mobile No. | |
| | E-mail Address : | |
| 03. | GST No. | |
| 04. | Status of the firm with supporting documents | Proprietary /Partnership /Pvt. /Public Limited. |
| 05. | Name of Agencies/Directors if not prop. Name of owner, if propriety, with phone/Fax Nos. | |
| 06. | SSI/NSIC No. (Notarized copy) | |
| 07. | PAN No: | |

IMPORTANT NOTE

01. This tender should be submitted duly signed without removing a single page. Otherwise the tender is liable to be rejected.
02. For SUPPLY TENDER, GST number should be invariable mentioned in their technical bid otherwise your offer will be ignored and price bid will not be opened.

**Signature of Contractor with Place /
Date / Firm Seal / Stamp**

ANNEXURE-I

ON FIRM'S LETTER HEAD

I / We _____ Authorized signatory of

M/s. _____ here by certify that...

M/s. _____ is not related with other firms who

have submitted tenders for the same items under this Tender.

Seal of the Firm :

Place :

Signature of the Tenderer :

Date with Designation:

Annexure-II

DEVIATION FROM BIDDER (IF ANY)

NOTE:-

1. GSECL does not bind to accept the deviation offered by bidder for evaluation of tender.
2. If there is any deviation from bidder, it should be clearly mentioned on this page.
3. Deviation mentioned on other page should not be considered and order will be placed according to the tender documents.
4. If there is no any deviation from bidder, than it must be clearly mentioned in this page “NO DEVIATION OFFERRED”

Signature of the Contractor
With seal

UNDERTAKING IN REGARD TO STOP DEAL / BLACK LIST THEREOF

All bidders will have to furnish the following undertaking duly filled in, signed and stamped for each quoted item of the tender along with the Technical Bid.

I/We _____

Authorized signatory of M/s _____

_____ here by certify that

M/s _____

_____ is not stop deal/black listed by GUVNL and or their any subsidiary company viz. GSECL/GETCO/DGVCL/MGVCL / UGVCL / PGVCL.

Signature of the Tenderer
Seal of the Firm

INTEGRITYPACT - OUR ENDEAVOUR

To create an environment where Business Confidence is built through Best Business Practices and is fostered in an atmosphere of trust and respect between providers of goods and services and their users for the ultimate benefit of society and the nation.

| | GSECL'S COMMITMENT | | PARTY'S COMMITMENT |
|---|--|---|--|
| % | To maintain the highest ethical standards in business and professions. | % | Not to bring pressure recommendations from outside GSECL to influence its decision. |
| % | Ensure maximum transparency to the satisfaction of stakeholders. | % | Not to use intimidation, threat, inducement or pressure of any kind on GSECL or any of its employees under any circumstances. |
| % | To ensure to fulfill the terms of agreement / contract and to consider objectively the viewpoint of parties. | % | To prompt and reasonable in fulfilling the contract, agreement, legal obligations. |
| % | To ensure regular and timely release of payments on due dates for work done. | % | To provide goods and / or services timely as per agreed quality and specifications at minimum cost to GSECL. |
| % | To ensure that no improper demand is made by employees or by any one on our behalf. | % | To abide by the general discipline to be maintained in our dealings. |
| % | To give maximum possible assistance to all the Vendors / Suppliers / Service Provider and other to enable them to complete the contract in time. | % | To be true and honest in furnishing information. |
| % | To provide all information to Suppliers / Contractors relating to contract / job which facilitate him to complete the contract / job successfully in time. | % | Not to divulge any information, business details available during the course of business relationship to other without the written consent of GSECL. |
| % | To ensure minimum hurdles to vendors / suppliers / contractors in completion of agreement / contract / work order. | % | Not to enter in to carter / syndicate / understanding whether formal / non-formal so as to influence the price. |

Seal & Signature
(Party's Authorized Person)
Name:

Seal & Signature
(GSECL's Authorized Signatory)
Name :
Designation :



GUJARAT STATE ELECTRICITY CORPORATION LIMITED

VIDYUT BHAVAN, RACE COURSE, VADODARA - 390 007. TEL: 0265-6612101, FAX: 0265-2344537,
e-mail: cegen.gsecl@gebmail.com, gm.f.gsecl@gebmail.com, cepn.gsecl@gebmail.com;
WEB: WWW.GSECL.IN, AN ISO-9001-2008 CERTIFIED COMPANY

90060000:DHUVARAN THERMAL POWER STATION - 388610

SCHEDULE-B (Price Bid)

Description: Supply of lighting materials & consumable items for EMD CCPP, Dhuvaran GBPS

Reference No.: DGBPS/TECH/EMD-III/62(19)/RFQ-49382

E-Urja RFQ No.: 49382

| Sr. No. | Description of materials with details of Specifications | HSN CODE | GST Rate With Cess If Any IN % | Quantity Required | UOM | Quantity Offered by Tenderer | Unit Ex-Work In Rs. | Packaging and Forwarding Charges per Unit in Rs. | GST in Rs per unit. | Insurance Charges per unit in Rs. | Freight Charges per unit in Rs. | Unit End Cost Price in Rs. | Total End Cost Price in Rs. |
|---------|---|----------|--------------------------------|-------------------|---------|------------------------------|---------------------|--|---------------------|-----------------------------------|---------------------------------|----------------------------|-----------------------------|
| 1 | 50W LED FLOOD LIGHT WITH ALUMINUM BODY. | | | 33 | Number | | | | | | | | |
| 2 | LED LAMP 9 WATT, 230V | | | 34 | Number | | | | | | | | |
| 3 | 25W LED STREET LIGHT WITH PRESSURE DIE CAST HOUSING WITH TOUGHENED GLASS WITH IP65 PROTECTION | | | 56 | Numbers | | | | | | | | |
| 4 | 150 Watt LED High Bay light fitting | | | 52 | Numbers | | | | | | | | |
| 5 | 40 WATT LED LAMPS INDUSTRIAL WELL GLASSED LUMINARI ,SEPARATE CONTROL GEAR BOX WITH COMPLETE FITTING | | | 160 | Number | | | | | | | | |
| 6 | LED HIGH BAY LIGHT FITTING 90 WATT | | | 27 | Number | | | | | | | | |
| 7 | LED FLOOD LIGHT FIXTURE 150 WATT | | | 15 | Number | | | | | | | | |
| 8 | LOW BAY LED LIGHT 45 WATT, DOME TYPE FITTING. | | | 16 | Number | | | | | | | | |
| 9 | LED BULB, WATTAGE = 14W, BASE = E-27 (SCREW TYPE), LUMENS = 1400 LM, INPUT SUPPLY = 220-240 V AC, | | | 131 | Number | | | | | | | | |

| | | | | | | | | | | | | | |
|----|--|--|--|-----|---------|--|--|--|--|--|--|--|--|
| | 50 HZ. | | | | | | | | | | | | |
| 10 | LED BULB, WATTAGE = 7W, BASE = E-27 (SCREW TYPE), LUMENS = 700 LM, INPUT SUPPLY = 220-240 V AC, 50 HZ. | | | 31 | Number | | | | | | | | |
| 11 | SCREW TYPE COPPER CAP PORCELIN BATTON LAMP HOLDER 100/200W, 250V AC, HEAVY DUTY | | | 175 | Number | | | | | | | | |
| 12 | LED AVIATION OBSTRUCTION WARNING LIGHTS,(MEDIUM INTENSITY,TYPE-B),INTENSITY:1600 TO 2000CD.360 DEGREE ALL ROUND UNIFORM VISIBILITY,COLOR: RED, FLASHING:20TO60FLASH PER MINUTE,PROTECTION:WEATHER PROOF:IP 65,VOLTAGE: 230 V AC, +/- 15% | | | 6 | Number | | | | | | | | |
| 13 | ENERGY SAVER CEILING FAN AS PER BEE STANDARD [IS:374] WITH 1200 MM SWEEP | | | 17 | Number | | | | | | | | |
| 14 | PVC ADHESIVE INSULATION TAPE ROLL | | | 300 | Number | | | | | | | | |
| 15 | HT PVC INSULATION TAPE SIZE 0.18 MM X25 MM X 65 MTR LENGTH | | | 4 | Roll | | | | | | | | |
| 16 | NYLONE ROPE 20 MM DIA | | | 60 | Meter | | | | | | | | |
| 17 | MANILA ROPE 3/4" | | | 60 | Meter | | | | | | | | |
| 18 | RUSTOLENE 500 ML/TIN | | | 50 | Number | | | | | | | | |
| 19 | RUST REMOVING SPRAY WD-40 IN AERSOLE PACKING OF HIGH PRESSURE VALVES . | | | 50 | Number | | | | | | | | |
| 20 | WIRE BRUSH SIZE 12" WITH WOODEN HANDLE | | | 5 | Number | | | | | | | | |
| 21 | 415V OFFLINE CONTACT CLEANER (700ML TIN) | | | 30 | Number | | | | | | | | |
| 22 | SINGLE PHASE AC 250/24VOLTS, 500VA TRANSFORMER MOUNTED IN SMC BOX WITH TWO 5/15 AMP PLUGS AND SWITCHES IN 24VOLT SIDE AND FUSE IN 250VOLT SIDE SUITABLE FOR MOUNTING ON STRUCTURE. | | | 2 | Numbers | | | | | | | | |
| 23 | HAND LAMP 100 WATT SCREW TYPE | | | 20 | Number | | | | | | | | |

| | | | | | | | | | | | | | |
|----|--|--|--|-----|-------|--|--|--|--|--|--|--|--|
| | COMPLETE WITH GLASS, GUARD AND 10 METER TWO CORE, 1.0 SqMM INSULATED FLEXIBLE WIRE | | | | ers | | | | | | | | |
| 24 | COPPER FLEXIBLE WIRE 3 CX2.5 SqMM, 1.1 KV | | | 600 | Meter | | | | | | | | |
| 25 | FLEXIBLE PVC HARD PIPE SIZE 0.75" | | | 120 | Meter | | | | | | | | |

Note : Technical Specification and Terms & Condition as per technical bid

Yours Faithfully,

**(Signature of the Tenderer)
(With Company's Round Seal)**

Yours Faithfully

**-----S/D-----
Addl. Chief Engineer. (Gen)
GSECL, DGBPS**

Note: Price bid is required to be submitted in online only, physical submission of the price bid will not be considered.