

### **40W LED DOWN LIGHT CW**

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

**40W Energy Efficient LED Light** 

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 02/19/2019

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

### **Test Report**

Report Number: 19-02-20	19 -001		Date:	19-02-2019	
<b>Product Description:</b> 40W Energy Efficient LED Down Light					
Product Catalogue Reference:	HLDLR-R27S-40-CW		Brand:	HALONIX	
Aluminum spun housing, PS/PC diffu	ser, etc.				
Test Details	<b>5</b> :	Document I	Document References/Standard:		
<ul> <li>Light intensity distribution Measurement</li> <li>Total Lumen output Measurement</li> <li>Electrical Parameters Measurement</li> </ul>		<ul> <li>IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products"</li> <li>IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products"</li> <li>IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources"</li> </ul>			
Enclosures:					
Prepared By:		A	pproved B	у:	
Sanjay Sharma		Rajeev Chhabra			

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Electrical & Photometric Test Report**

Photometric Test Report: (As P	Per IES LM 79-08)				
Sample ID: 19-02-2019 -001					
Catalogue Reference:	HLDLR-R27S-40-CW	Testing Date:	19-02-2019		
Testing Agency:	HTPL Laboratory	Brand:	HALONIX		
<b>Equipment Used:</b> EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe					
	Photometer (Type: PMS – 50/80) with Power Meter				
	25.200 5.1.1 11 111	650/			

Ambient Temperature:	25±2°C	Relative Humidity:	65%
Test Voltage:	240V	Frequency:	50Hz
Stabilization Time:	30Min	<b>Total Operating Time:</b>	1.30Hours

Rated Performance Parameters:				
Rated Wattage :	40W	Rated Input Current:	0.193A	
Nomical CCT :	6500K	Nominal CRI:	>80	

Measured Electrical Parameters:				
Supply Voltage:	240V	Input Current :	0.169A	
Frequency:	50Hz			
Total Power :	39.85W	Power Factor :	0.982	

Photometric Measurement Data:				
Total Measured Lumen :	4029.23lm	<b>Luminaries Efficacy:</b>	101.11lm/W	
CCT:	6468K	CRI:	81.5	
Light Intensity Distribution:		Attached (Refer to Page No. 4)		
Approved By: Rajeev Chhabra		Tested By: Sanjay Sharma		

### HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India


Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Light intensity Distribution Diagram**



-			
Catalogue Reference	HLDLR-R27S-40-CW	Sample ID	19-02-2019 -001