

### **18W LED BATTEN CW**

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

**18W Energy Efficient LED Light** 

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 06/18/2019

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Test Report**

Report Number: 18-06-2019	9 -003			Date:	18-06-2019
Product Description: 18W Energy Efficient LED Batten					
Product Catalogue Reference:	HLB-03-18-CW-AL-HL2			Brand:	HALONIX
Construction:					
Aluminum housing, PC diffuser, etc.					
Test Details:		Document References/Standard:			
<ul> <li>Light intensity distribution Measurement</li> <li>Total Lumen output Measurement</li> <li>Electrical Parameters Measurement</li> </ul>		<ul> <li>IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products"</li> <li>IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products"</li> <li>IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources"</li> </ul>			
Enclosures:		1	Α		
Prepared By:		1	A	pproved B	<b>y</b> :
Sanjay Sharma		Rajeev Chhabra			

## HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

### **Electrical & Photometric Test Report**

Photometric Test Report: (As Per IE	S LM 79-08)				
Sample ID: 18-06-2019 -003					
Catalogue Reference:	HLB-03-18-CW-AL-HL2		<b>Testing Date:</b>	18-06-2019	
Testing Agency:	HTPL Laborat	HTPL Laboratory		HALONIX	
Equipment Used:	EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe				
	Photometer (Type: PMS – 50/80) with Power Meter				
		1			
Ambient Temperature:	25±2°C	Relative Humidity:	65%		
Test Voltage:	240V	Frequency:	50Hz		
Stabilization Time:	30Min	<b>Total Operating Time:</b>	1.30Hours		
Rated Performance Parameters:					
Rated Wattage :	18W	Rated Input Current:	0.087A		
Nomical CCT :	6500K	Nominal CRI:	>80		
Measured Electrical Parameters:					
Supply Voltage:	240V	Input Current :	0.076A		
Frequency:	50Hz				
Total Power :	17.95W	Power Factor :	0.984		
Γ.					
Photometric Measurement Data:					
Total Measured Lumen :	2191.87lm	Luminaries Efficacy:	122.11lm/W		
CCT:	6310K	CRI:	82.5		
Light Intensity Distribution:		Attached (Refer to Page No. 4)			
Approved By: Rajeev Chhabra		Tested By: Sanjay Sharma			

### HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India


Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Light intensity Distribution Diagram**



Catalogue Reference	HLB-03-18-CW-AL-HL2	Sample ID	18-06-2019 -003