

18W LED DOWN LIGHT CW

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

18W Energy Efficient LED Light

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 02/06/2019

HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

Test Report

Report Number: 06-02-2019 -002	Date:	06-02-2019	
Product Description: 18W Energy Efficient LED Down Light			
Product Catalogue Reference: HLDLR-31-18-CW	Brand:	HALONIX	
Construction: Aluminum die cast housing, PMMA diffuser, etc.			
Test Details:	Document References	s/Standard:	
 Light intensity distribution Measurement Total Lumen output Measurement Electrical Parameters Measurement 	 IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products" IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products" IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources" 		
Enclosures:			
Prepared By:	Approved By:		
Sanjay Sharma	Rajeev Chhabra		

HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

Electrical & Photometric Test Report

.DLR-31-18-CW	letter ber	-	
DLR-31-18-CW	Tarifa Bara		
22.1. 22 20 211	Testing Date:	06-02-2019	
「PL Laboratory	Brand:	HALONIX	
EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe Photometer (Type: PMS – 50/80) with Power Meter			
	la-ar		
1	otometer (Type: PMS – 50/80) v	• • • • • • • • • • • • • • • • • • • •	

Ambient Temperature:	25±2°C	Relative Humidity:	65%
Test Voltage:	240V	Frequency:	50Hz
Stabilization Time:	30Min	Total Operating Time:	1.30Hours

Rated Performance Parameters:			
Rated Wattage :	18W	Rated Input Current:	0.087A
Nomical CCT :	6500K	Nominal CRI:	>80

Measured Electrical Parameters:			
Supply Voltage:	240V	Input Current :	0.075A
Frequency:	50Hz		
Total Power :	17.69W	Power Factor :	0.983

Photometric Measurement Data:			
Total Measured Lumen :	1803.67lm	Luminaries Efficacy:	101.96lm/W
CCT:	6410K	CRI:	82.3
Light Intensity Distribution:	ensity Distribution: Attached (Refer to Page No. 4)		. 4)
Approved By: Rajeev Chhabra		Tested By: Sanjay Sharma	

HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India


Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

Light intensity Distribution Diagram



Catalogue Reference	HLDLR-31-18-CW	Sample ID	06-02-2019 -002