

Bid Document

Bid Details	
Bid End Date/Time	13-01-2020 17:00:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Defence
Department Name	Department Of Defence Production
Organisation Name	Indian Ordnance Factories
Office Name	Metal & Steel Factory, Ishapore
Total Quantity	200
Item Category	LED Luminaire (For Road and Street Lights)
MSE Exemption For Years Of Experience And Turnover	No
Startup Exemption For Years Of Experience And Turnover	No
Bid to RA enabled	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

MSE Purchase Preference

MSE Purchase Preference	Yes
-------------------------	-----

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small

Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.

LED Luminaire (For Road And Street Lights) (200 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	LED Luminaire conformity to IS:10322/Part 5/Section 3/2012 latest and IS: 16107 (Part 2/Sec 1):2012 latest	Yes	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	Types of LED Luminaire as per the IS: 16107(Part-2/ Sec.-1)/2012	Type B	*
	Types of LED Modules as per the IS:IS: 16103(Part-2)/2012	Type 3	*
	LED Rating (in Watts)/System Wattage/Rated Power	36W	36W
	Luminaire System Efficacy (Lumen/watt)	>/= 100 Lm/Watt	*
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66	*
	Warranty for free replacement (in years)	3	3
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	140 to 270 V olts AC at 50 Hz+/-2 with auto cutt off at below 120V	*
	Automatic Higher Cut	Yes	*

	off voltage above 300 volt		
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor at full load	≥ 0.95	*
	Driver Efficiency (in %age) Upto 100W: $\geq 85\%$, Above 100W: $\geq 90\%$	Yes	*
	Total Harmonics Distortion	≤ 10	*
	"The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl. 8 of IS:16104:2012 lates)"	Yes	*
OPTICAL	LED chip Efficacy	≥ 130 Lm/Watt	*
	Colour temperature	6000+/-500K	*
	Working life for LED (Minimum 50,000 burning hours as per LM-80 and LM 21 reports)	Yes	*
	Colour Rendering Index(CRI)	≥ 70	*
	LED Beam Angle	≥ 120	*
	Optic lense material (UV stabilised)	Poly carbonate lense	*
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes	*
	Junctiojn / Soldering point temperature shall not exceed 85 deg.c as per LM 80 report	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Operating temperature range	-10 deg C to +50 deg C	-10 deg C to +50 deg C
	Operating Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*

	Over load protecton	Yes	*
	Over Voltage protection	Yes	*
	Reverse polarity	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M Ohm	*
	The luminaire shall be protected against surges and transients (Internal)	>/=5KV	*
	The luminaire shall be protected against surges and transients of >/=10KV (External)	Yes	*
CONSTRUCTIONAL	The Luminaires casing/housing (single piece housing) shall be pressure die casted aluminium alloy with higher thermal conductivity	Yes	*
	The luminaire body must be corrosion resistant powder coated	Yes	*
	All fastners must be of stainless steel	Yes	*
	Protection of the entire housing (both LED section and driver section) as per IS:10322 (Part 1):1982 latest	IP66	*
	Extruded silicon loop gasket shall be provided in the lantern body to ensure a weather proof seal between the UV Glass cover and the metal housing to exclude the entry of the dust, water, insects etc.,	Yes	*
	Luminaries light transparency should be of Toughened glass	Yes	*

Toughened transparent glass cover thickness	>=4 mm	*
Toughened Glass shall not get discoloured shall not suffer degradation due to heat and ageing within warranty period	Yes	*
Number of electronic control gear (power supplies)	1 No.	1 No.
Light Source	SMD LED Chip as per LM 80/IS16106	*
Driver components shall be industrial grade or above	Yes	*
PCB shall be FR4 grade minimum 0.8 to 1.0 mm thick or more	Yes	*
The Luminaires works on single phase three wires system (Phase, Neutral and Earth)	Yes	*
Suitable connector shall be provided for LED connection between driver output and LED	Yes	*
Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm	50 cm
MARKING	"Manufactures Name and and brand on the aluminium die cast body "	Engraved/Embossed
	Manufacturer's name, model number, serial number	Yes
	Date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes
	The operation characteristics voltage and power be marked inside of each LED	Yes

	luminaire unit		
	Diameter of pole Luminaire suitable for: (upto 45W Pole OD: shall be 40mm), (>45W<120W Pole OD: Shall be 50 mm), (above 120W: OD shall be 60 mm for which luminaire is suitable	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND	*
	System must have EMI/EMC compliance as applicable (Test reports shall be furnish to the buyer / consignee on demand)	Yes	*
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
	LM 80 & TM 21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-80 report shall have the Photo Biological report of the LED Chip being used in the luminaire)	Yes	*
	Availability of test Report from Central Government Lab	Yes	*

	/NABL/ILAC accredited lab to Indian Standard IS:10322/part 5/sec-3/2012 and IS 16107 (Part 2/Sec 1) : 2012		
	Seller shall furnish the Type test reports to the buyer / consignee on demand	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	LED Luminaire for road and street lighting shall comply with Compulsory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 3): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Binod Kumar Paswan	743144,PO - Ichhapur Nawabganj, North 24 Parganas	200	30

Bid Specific Additional Terms and Conditions

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given

opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.

2. Purchase preference to Micro and Small Enterprises (MSEs) from the State of Bid Inviting Authority : Purchase preference will be given to MSEs as Micro and Small Enterprises from the State of Bid inviting Authority whose credentials are validated online through Udyog Aadhaar for that product category. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15 % of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value as defined/ decided in relevant policy.
3. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
4. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---