

### 18W LED MOD DOWN LIGHT CW

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

**18W Energy Efficient LED Light** 

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 08/29/2019

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

### **Test Report**

<b>Report Number:</b> 29-08-2019 -002	Date:	29-08-2019	
Product Description: 18W Energy Efficient LED MOD Down Light			
Product Catalogue Reference: HLDLS-R06-18-CW	Brand	: HALONIX	
Construction: Aluminum die cast housing, PMMA diffuser, etc.			
Test Details:	Document Referen	ces/Standard:	
<ul> <li>Light intensity distribution Measurement</li> <li>Total Lumen output Measurement</li> <li>Electrical Parameters Measurement</li> </ul>	<ul> <li>IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products"</li> <li>IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products"</li> <li>IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources"</li> </ul>		
Enclosures:			
Prepared By:	Prepared By: Approved By:		
Sanjay Sharma	Rajeev Chhabra		

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

### **Electrical & Photometric Test Report**

Photometric Test Report: (As	Per IES LM 79-08)				
<b>Sample ID:</b> 29-08-2019 -002					
Catalogue Reference:	HLDLS-R06-	HLDLS-R06-18-CW		29-08-2019	
Testing Agency:	HTPL Labor	HTPL Laboratory		HALONIX	
Equipment Used:		EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe			
	Photomete	Photometer (Type: PMS – 50/80) with Power Meter			
Ambient Temperature:	25±2°C	Relative Humidity:	65%		
Test Voltage:	240V	Frequency:	50Hz		
Stabilization Time:	30Min	Total Operating Time:	1.30Hours		
Rated Performance Parameters	<u> </u>				

Rated Performance Parameters:			
Rated Wattage :	18W	Rated Input Current:	0.087A
Nomical CCT :	6500K	Nominal CRI:	>80

Measured Electrical Parameters:				
Supply Voltage:	240V	Input Current :	0.076A	
Frequency:	50Hz			
Total Power :	17.97W	Power Factor :	0.985	

Photometric Measurement Data:				
Total Measured Lumen :	1362.31lm	Luminaries Efficacy:	75.81lm/W	
CCT:	6410K	CRI:	82.7	
Light Intensity Distribution:		Attached (Refer to Page No. 4)		
Approved By: Rajeev Chhabra Tested By: Sanjay Sharma				

### HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India


Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

### **Light intensity Distribution Diagram**



5			
Catalogue Reference	HLDLS-R06-18-CW	Sample ID	29-08-2019 -002