



**एनएलसी इंडिया लिमिटेड**  
 ('नवरत्न'-भारत सरकार का उपक्रम)  
**NLC INDIA LIMITED**  
 (formerly Neyveli Lignite Corporation Limited)  
 ('NAVARATNA'-Government of India Enterprise)  
**बरसिंहसर परियोजना, संविदा एवं क्रय प्रभाग**  
**BARSINGSAR PROJECT, CONTRACTS & PURCHASE DIVISION**  
 प्र. का. भवन, बरसिंहसर-334402, जिला बीकानेर, राजस्थान  
 A.O Building, Barsingsar-334402, Bikaner District, Rajasthan, India  
 दूर भा: 0151-2847574 फेक्स: 0151-2847511  
 Phone: 0151-2847574 Fax: 0151-2847511  
 GST:08AAACN1121C1Z9 E-mail: dgmbp.contracts@nlcindia.com

निविदा जाँच सं: /TENDER ENQUIRY NO :ENQ/19-20/003140/BP26(07) दिनांक/DATE :14/01/2020 पृष्ठ /Page - 1

**Due Date of Cover-I Opening : 30/01/2020 15:00:00 hrs. IST (Check NLC eproc website for any change in due date of opening.)**  
**Note : Quotation should be valid for 120 days from the date of opening.**

Gentlemen,

We shall be glad to receive your lowest online offer submitted through <http://eproc.nlcindia.com> for the material mentioned below, subject to our terms and conditions. Any other mode of offer will be rejected. Please indicate the enquiry number in all future correspondence. Offer details of the participating bidders will be available online after the tender is opened.

क्र.सं. SI No.	विवरण Details	माप की इकाई UOM	मात्रा Quantity																																
1	<div><div>विनिर्देश Specification</div><div>30 021 0771 : 40W LED WELL GLASS FITTING HANGING TYPE WITH DRIVER UNIT.</div><table><tr><th>क्र.सं. SI No.</th><th>तकनीकी कारक Technical Factor(s)</th></tr><tr><td>1</td><td>40W LED Well glass fitting hanging type with driver unit</td></tr><tr><td>2</td><td>LED Rating/System Wattage : 40W</td></tr><tr><td>3</td><td>Make of the Fitting or luminaire shall be anyone of the following only: Venture/Syska/Bajaj/Havells/Capart/Halonix/HPL. Any one make to be mentioned and the mentioned make to be offered.Model also to be mentioned .</td></tr><tr><td>4</td><td>The make of the LED shall be any one of the following: OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND.The offered LED make to be mentioned.</td></tr><tr><td>5</td><td>Housing:Powder coated pressure die cast aluminium housing with extended heat sink for effective thermal management.</td></tr><tr><td>6</td><td>Rated Voltage : 230V AC , 50HZ</td></tr><tr><td>7</td><td>Luminaire System Efficacy : &gt;=100 lm/W.</td></tr><tr><td>8</td><td>Color Temperature :(5500 - 6500 deg K)</td></tr><tr><td>9</td><td>The luminaire ingress protection shall be: IP 65/IP 66 or better</td></tr><tr><td>10</td><td>Driver Protection:Inbuilt Over volatage,short circuit &amp; Surge Protection system</td></tr><tr><td>11</td><td>The luminaire shall have hanging type with eyebolt mounting.Suitable stainless steel bolt,nut and washers for each luminaire shall also be supplied along with the luminaire at free of cost</td></tr><tr><td>12</td><td>1.The test certificates (LM79-08/IS-16106-2012 Test report for luminaire) shall be furnished free of cost obtained either from the laborites approved by BIS (or) from the laboratories accredited by NABL (or) from Manufacturers if they are ISO Certified company. 2.The current validity of accreditation/ approval/ ISO Certification for Laboratory / Manufacturer shall also be furnished. 3. The LM80: Test report for LED from the LED manufacture shall be furnished at free of cost along with bulk supply</td></tr></table><div><div>वितरण अनुसूची Delivery Schedule</div><table><tr><th>Delivery Type</th><th>Period From PO Date (Days)</th><th>Quantity</th></tr><tr><td>F.O.R at Barsingsar Stores</td><td>0 to 60</td><td>300.0000</td></tr></table></div></div> <td>Number</td> <td>300.0000</td>	क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)	1	40W LED Well glass fitting hanging type with driver unit	2	LED Rating/System Wattage : 40W	3	Make of the Fitting or luminaire shall be anyone of the following only: Venture/Syska/Bajaj/Havells/Capart/Halonix/HPL. Any one make to be mentioned and the mentioned make to be offered.Model also to be mentioned .	4	The make of the LED shall be any one of the following: OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND.The offered LED make to be mentioned.	5	Housing:Powder coated pressure die cast aluminium housing with extended heat sink for effective thermal management.	6	Rated Voltage : 230V AC , 50HZ	7	Luminaire System Efficacy : >=100 lm/W.	8	Color Temperature :(5500 - 6500 deg K)	9	The luminaire ingress protection shall be: IP 65/IP 66 or better	10	Driver Protection:Inbuilt Over volatage,short circuit & Surge Protection system	11	The luminaire shall have hanging type with eyebolt mounting.Suitable stainless steel bolt,nut and washers for each luminaire shall also be supplied along with the luminaire at free of cost	12	1.The test certificates (LM79-08/IS-16106-2012 Test report for luminaire) shall be furnished free of cost obtained either from the laborites approved by BIS (or) from the laboratories accredited by NABL (or) from Manufacturers if they are ISO Certified company. 2.The current validity of accreditation/ approval/ ISO Certification for Laboratory / Manufacturer shall also be furnished. 3. The LM80: Test report for LED from the LED manufacture shall be furnished at free of cost along with bulk supply	Delivery Type	Period From PO Date (Days)	Quantity	F.O.R at Barsingsar Stores	0 to 60	300.0000	Number	300.0000
क्र.सं. SI No.	तकनीकी कारक Technical Factor(s)																																		
1	40W LED Well glass fitting hanging type with driver unit																																		
2	LED Rating/System Wattage : 40W																																		
3	Make of the Fitting or luminaire shall be anyone of the following only: Venture/Syska/Bajaj/Havells/Capart/Halonix/HPL. Any one make to be mentioned and the mentioned make to be offered.Model also to be mentioned .																																		
4	The make of the LED shall be any one of the following: OSRAM / NICHIA/CREE / SAMSUNG / SEOUL / LUMILED / PHILIPS / EDISON / SYSKA / LUMENMAX / EVERLIGHT / BRIDGELUX / NATIONSTAR / REFOND.The offered LED make to be mentioned.																																		
5	Housing:Powder coated pressure die cast aluminium housing with extended heat sink for effective thermal management.																																		
6	Rated Voltage : 230V AC , 50HZ																																		
7	Luminaire System Efficacy : >=100 lm/W.																																		
8	Color Temperature :(5500 - 6500 deg K)																																		
9	The luminaire ingress protection shall be: IP 65/IP 66 or better																																		
10	Driver Protection:Inbuilt Over volatage,short circuit & Surge Protection system																																		
11	The luminaire shall have hanging type with eyebolt mounting.Suitable stainless steel bolt,nut and washers for each luminaire shall also be supplied along with the luminaire at free of cost																																		
12	1.The test certificates (LM79-08/IS-16106-2012 Test report for luminaire) shall be furnished free of cost obtained either from the laborites approved by BIS (or) from the laboratories accredited by NABL (or) from Manufacturers if they are ISO Certified company. 2.The current validity of accreditation/ approval/ ISO Certification for Laboratory / Manufacturer shall also be furnished. 3. The LM80: Test report for LED from the LED manufacture shall be furnished at free of cost along with bulk supply																																		
Delivery Type	Period From PO Date (Days)	Quantity																																	
F.O.R at Barsingsar Stores	0 to 60	300.0000																																	

आपका प्रस्ताव एन.एल.सी. स्टोर्स बरसिंहसर के यहाँ द्वार वितरण आधार पर होना चाहिए।  
**YOUR OFFER SHOULD BE ON DOOR DELIVERY BASIS AT NLC STORES BARSINGSAR**  
 निरीक्षण खंड /Inspection Clause : Inspection at Barsingsar  
 गारंटी की आवश्यकताएँ /Guarantee Requirement : The firm should furnish two years warranty for supplying materials from the date of supply in the firms letter head.

संलग्नक Terms and Conditions of Enquiry  
 Attachments :

**NABL ACCREDITED LAB FOR CHEMICAL AND MECHANICAL TESTING OF MATERIALS IS AVAILABLE AT NLC. INTERESTED SUPPLIERS MAY VIEW THE DETAILS INCLUDING TESTING CHARGES AVAILABLE AT NLC'S WEBSITE <http://www.nlcindia.com>.**



**एनएलसी इंडिया लिमिटेड**  
 ('नवरत्न'-भारत सरकार का उपक्रम)  
**NLC INDIA LIMITED**  
 (formerly Neyveli Lignite Corporation Limited)  
 ('NAVARATNA'-Government of India Enterprise)  
**बरसिंहसर परियोजना, संविदा एवं क्रय प्रभाग**  
**BARSINGSAR PROJECT, CONTRACTS & PURCHASE DIVISION**  
 प्र. का. भवन, बरसिंहसर-334402, जिला बीकानेर, राजस्थान  
**A.O Building, Barsingsar-334402, Bikaner District, Rajasthan, India**  
 दूर. भा: 0151-2847574 फेक्स: 0151-2847511  
 Phone: 0151-2847574 Fax: 0151-2847511  
 GST: 08AAACN1121C1Z9 E-mail: dgmbp.contracts@nlcindia.com

निविदा जाँच सं: /TENDER ENQUIRY NO :ENQ/19-20/003140/BP26(07)		दिनांक/DATE :14/01/2020	पृष्ठ /Page - 2
क्र.सं. Sl No.	विवरण Details	माप की इकाई UOM	मात्रा Quantity
	<p style="text-align: center;"><b>परीक्षण प्रमाणपत्र</b> <b>Test Certificate</b></p> <p>1.The test certificates (LM79-08/IS-16106-2012 Test report for luminaire) shall be furnished free of cost obtained either from the laborites approved by BIS (or) from the laboratories accredited by NABL (or) from Manufacturers if they are ISO Certified company. 2.The current validity of accreditation/ approval/ ISO Certification for Laboratory / Manufacturer shall also be furnished. 3. The LM80: Test report for LED from the LED manufacture shall be furnished at free of cost along with bulk supply</p>		

**BIDDERS ARE ADVISED TO QUOTE THE MOST COMPETITIVE PRICE IN THE INITIAL BID AS WELL AS IN THE REVERSE AUCTION (RA), WHEREVER APPLICABLE, SINCE THERE WILL NOT BE POST TENDERING NEGOTIATIONS WITH THE L1 BIDDER UNDER ANY CIRCUMSTANCES.**