

### 12W LED MOD DOWN LIGHT CW

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

**12W Energy Efficient LED Light** 

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 09/18/2019

## HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

### **Test Report**

<b>Report Number:</b> 18-09-2019 -003	Date	18-09-2019	
Product Description: 12W Energy Efficient LED MOD Down Light			
Product Catalogue Reference: HLDLR-S06-12-CW	Brand	: HALONIX	
Construction: Aluminum die cast housing, PMMA diffuser, etc.			
Test Details:	Document Referen	ces/Standard:	
<ul> <li>Light intensity distribution Measurement</li> <li>Total Lumen output Measurement</li> <li>Electrical Parameters Measurement</li> </ul>	<ul> <li>IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products"</li> <li>IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products"</li> <li>IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources"</li> </ul>		
Enclosures:			
Prepared By:	Approved	l By:	
Sanjay Sharma	Rajeev Chhabra		

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

### **Electrical & Photometric Test Report**

Photometric Test Report: (As Per IES	LM 79-08)		
Sample ID: 18-09-2019 -003			
Catalogue Reference:	HLDLR-S06-12-CW	Testing Date:	18-09-2019
Testing Agency:	HTPL Laboratory	Brand:	HALONIX
Equipment Used:	EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe		
	Photometer (Type: PMS – 50/80) with Power Meter		

Ambient Temperature:	25±2°C	Relative Humidity:	65%
Test Voltage:	240V	Frequency:	50Hz
Stabilization Time:	30Min	<b>Total Operating Time:</b>	1.30Hours

Rated Performance Parameters:			
Rated Wattage :	12W	Rated Input Current:	0.058A
Nomical CCT :	6500K	Nominal CRI:	>80

Measured Electrical Parameters:				
Supply Voltage:	240V	Input Current :	0.051A	
Frequency:	50Hz			
Total Power :	11.88W	Power Factor :	0.971	

Photometric Measurement Data:			
Total Measured Lumen :	845.97lm	Luminaries Efficacy:	71.21lm/W
CCT:	6331K	CRI:	82.3
Light Intensity Distribution:		Attached (Refer to Page No. 4)	
Approved By: Rajeev Chhabra		Tested By: Sanjay Sharma	

### HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India


Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Light intensity Distribution Diagram**



Catalogue Reference	HLDLR-S06-12-CW	Sample ID	18-09-2019 -003