

18W LED TUBE LIGHT CW

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

18W Energy Efficient LED Light

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 02/06/2019

HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

Test Report

Report Number: 06-02-2019 -001	Date:	06-02-2019	
Product Description: 18W Energy Efficient LED Tube Light			
Product Catalogue Reference: HLTLD-04-18-CW	Brand:	HALONIX	
Construction: Aluminum housing, PC diffuser, etc.			
Test Details:	Document Reference	es/Standard:	
 Light intensity distribution Measurement Total Lumen output Measurement Electrical Parameters Measurement 	 IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products" IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products" IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources" 		
Enclosures:			
Prepared By:	Approved By:		
Sanjay Sharma	Rajeev Chh	abra	

HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Total Power:

CCT:

Photometric Measurement Data:

Total Measured Lumen:

Light Intensity Distribution:

Approved By: Rajeev Chhabra

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

Electrical & Photometric Test Report

Photometric Test Report: (As P	er IES LM 79-08)			
Sample ID: 06-02-2019 -001				
Catalogue Reference:	HLTLD-04-1	HLTLD-04-18-CW		06-02-2019
Testing Agency:	HTPL Labor	HTPL Laboratory		HALONIX
Equipment Used:	EVERFINE B	EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe		
	Photomete	Photometer (Type: PMS – 50/80) with Power Meter		
Ambient Temperature:	25±2°C	Relative Humidity:	65%	
Test Voltage:	240V	Frequency:	50Hz	
Stabilization Time:	30Min	Total Operating Time:	otal Operating Time: 1.30Hours	
	-			
Rated Performance Parameters:				
Rated Wattage :	18W	Rated Input Current:	0.092A	
Nomical CCT :	6500K	Nominal CRI:	>80	
	•	•		
Measured Electrical Parameters:	1			
Supply Voltage:	240V	Input Current :	0.077A	
Frequency :	50Hz	-		

Power Factor:

CRI:

Luminaries Efficacy:

Attached (Refer to Page No. 4) **Tested By:** Sanjay Sharma

0.971

82.2

101.22lm/W

17.95W

1816.9lm 6418K

HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India


Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

Light intensity Distribution Diagram



Catalogue I	Reference	HLTLD-04-18-CW	Sample ID	06-02-2019 -001