



100W LED FLOOD LIGHT

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

100W Energy Efficient LED Flood Light

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634)

05/21/2019

HALONIX TECHNOLOGIES PRIVATE LIMITED**HTPL LABORATORY (NABL Certificate No: TC-7634)**

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: <http://www.halonix.co.in>

Test Report

Report Number:	21-05-2019 -001	Date:	21-05-2019
Product Description: 100W Energy Efficient LED Flood Light			
Product Catalogue Reference:	HLFLD-ML21-100-CWL-HL1	Brand:	HALONIX
Construction: Pressure die casted aluminum housing, Glass front visor, SMD LED, Electronic driver etc.			
Test Details:		Document References/Standard:	
<ul style="list-style-type: none">• Light intensity distribution Measurement• Total Lumen output Measurement• Electrical Parameters Measurement		<ul style="list-style-type: none">• IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products"• IS : 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products"• IS : 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources"	
Enclosures:			
Prepared By:		Approved By:	
Sanjay Sharma		Rajeev Chhabra	

HALONIX TECHNOLOGIES PRIVATE LIMITED
HTPL LABORATORY (NABL Certificate No: TC-7634)
 Plot-5, Sector-12, IIE, SIDCUL
 Haridwar (Uttarakhand), PIN-249403, India
 Contact:
 Email: customercare@halonix.co.in
 Fax:
 Web: <http://www.halonix.co.in>

Electrical & Photometric Test Report

Photometric Test Report: (As Per IES LM 79-08)			
Sample ID: 21-05-2019 -001			
Catalogue Reference:	HLFLD-ML21-100-CWL-HL1	Testing Date:	21-05-2019
Testing Agency:	HTPL Laboratory	Brand:	HALONIX
Equipment Used:	EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe Photometer (Type: PMS – 50/80) with Power Meter		

Ambient Temperature:	25±2°C	Relative Humidity:	65%
Test Voltage:	240V	Frequency:	50Hz
Stabilization Time:	30Min	Total Operating Time:	1.30Hours

Rated Performance Parameters:			
Rated Wattage :	100W	Rated Input Current :	0.482A
Nomical CCT :	5700K	Nominal CRI :	>70

Measured Electrical Parameters:			
Supply Voltage :	240V	Input Current :	0.425A
Frequency :	50Hz		
Total Power :	99.95W	Power Factor :	0.980

Photometric Measurement Data:			
Total Measured Lumen :	11089.45lm	Luminaries Efficacy :	110.95lm/W
CCT :	5847K	CRI :	72.2
Light Intensity Distribution:	Attached (Refer to Page No. 4)		
Approved By: Rajeev Chhabra	Tested By: Sanjay Sharma		

HALONIX TECHNOLOGIES PRIVATE LIMITED

HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: <http://www.halonix.co.in>

Light intensity Distribution Diagram



Catalogue Reference	HLFLD-ML21-100-CWL-HL1	Sample ID	21-05-2019 -001
---------------------	------------------------	-----------	-----------------