



UGANDA ELECTRICITY TRANSMISSION CO. LIMITED

METER AUDIT FORM

Location..... <u>Apac Hospital</u> <u>Lira-Masindi Feeder</u>	Meter Type: <u>CENE Promete</u> Meter S/No.: <u>CN/014540</u>
--	--

QUERY	DATE: <u>17/12/2020</u>
Missing current in one of the phases	

DIAGNOSIS	DATE: <u>17/12/2020</u>
<ul style="list-style-type: none"> - Interrogated the meter - Checked the installation - Downloaded data both instantaneous and historical - Carried out CT Analyse test on all the phases <p>NOTE: CTs & VTs are combined stand alone type (Dry type)</p>	