

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

: +91 (0265) 2638382 Fax

: erda@erda.org E-mail

Web : http://www.erda.org



TEST REPORT

SHEET: 1 of 4

NAME & ADDRESS OF CUSTOMER	TEST REPORT NO.	: RP-1819-019973	
Planetric Power LLP	DATE	: 22-08 - 2018	
MNO 3076 (Near Family Super Market), Pune- Nagar Road, A/P Wagholi, Tal-Haveli, Dist-Pune	CUSTOMER REF. NO & DATE	Letter, Dtd.: 17/07/2018	
412207	DATE OF SAMPLE RECEIPT	DATE OF TESTING	
MAHARASHTRA	06-08-2018	21-08-2018	
SAMPLE DESCRIPTION	SAMPLE IDENTIFICATION		
As Per Sheet 2 of 4	ERDA SAMPLE CODE NO. : ERDA-00271388		
	SR. NO.: 08/2018		

TEST DETAILS & TEST SPECIFICATION ARE AS PER SHEET NO.3 OF 4

1) Photograph of test sample as per Annexure-I Enclosures:

2) Drawing No. :1)A4 LTCT008/2018 2)LTCT008/2018

REMARKS: The sample Conforms to the requirement of the mentioned standard as mentioned in

test no. 1 on sheet no. 3 of 4.

PREPARED BY

CHECKED BY

APPROVED BY (SHAILESH PATEL)

Note:

- 1. This report relates only to the particular sample received for testing in good condition at ERDA vadodara.
- 2. This report cannot be reproduced in part under any circumstances.
- 3. Publication of this report requires prior permission in writing from Director, ERDA.
- 4. Only the tests asked for by the customer have been carried out.
- 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arised.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web: http://www.erda.org





TEST REPORT No.: RP-1819-019973

DATE: 22-08-2018

SHEET: 2 of 4

SAMPLE DESCRIPTION:

Current transformer

MFD, BY

PLANETRIC POWER LLP

Ratio

2500/5 A

Burden

15 VA

Class

1.0

ISF

<5

IL OR BIL

0.66/3.0 KV

Frequency

50 HZ F

Insulation Class

PREPARED BY

CHECKED BY

2583472



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail: erda@erda.org

Web: http://www.erda.org





TEST REPORT No.: RP-1819-019973

DATE: 22-08-2018

SHEET: 3 of 4

TEST DETAILS & TEST SPECIFICATIONS:

Sr.	TESTS	REFERENCE STANDARDS
1	Temperature rise test	IS 2705 PART 1 1992 CLAUSE NO. 9.7

PREPARED BY

CHECKED BY

AK.





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

: +91 (0265) 2638382

E-mail : erda@erda.org Web

: http://www.erda.org



TEST REPORT No.: RP-1819-019973

DATE: 22-08-2018

SHEET: 4 of 4

TEST RESULTS:

1) Temperature rise test

(IS 2705 PART 1 1992 CLAUSE NO. 9.7)

A Continuous rated thermal current equals to 100% of the rated primary current (i.e. 2500 A) at rated frequency was circulated in the primary winding of the CT.Rated burdens (15 VA) burdens were connected to the secondary winding terminals (i.e. S1-S2) of the CT. At steady state, the temperature of body and ambient were recorded. The

resistances of secondary windings were measured immediately after shut down.

Sr. No.	Temperature rise of	Specific limit for temperature rise test.	Obtained Value
1.	Secondary windings terminals (By Resistance Method)	105 °C	S1-S2: 30.14 °C
2.	body (By Thermocouple Method)	105 °C	22.2 °C
3,	Ambient temperature	40 °C	27,2 °C

Remark: Conforms

PREPARED BY

CHECKED BY




(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail: erda@erda.org
Web: http://www.erda.org





TEST REPORT No.: RP-1819-019973 DATE: 22-08-2018 SHEET: 1 of 1

PHOTOGRAPHS OF TEST SAMPLE



