(ii) In case the permissible coverage is not achieved with the above given setbacks, the setbacks of the immediate preceding category may be allowed.

(iii) The setbacks are subject to requirements of height and ventilation as per building byelaws.

(iv) In case a layout is sanctioned with more than the minimum prescribed setbacks, the same shall be followed in the sanction of the building plans.

(v) Technical Committee of DDA may relax setbacks, ground coverage and height in special circumstances.

(vi) No construction is permitted in set-back except those as per UBBL.

13.1.3 Basement

(i) Basement shall be permitted in all use premises, subject to approval of the concerned agencies/statutory bodies.

(ii) Basement shall not be counted towards FAR if used for incidental storage, services, utilities and parking.

(iii) In case the basement is used for activity in conformity with the use premises, wherever permitted, the same shall be counted in FAR subject to clearance from statutory bodies. In residential use premise, basement used for permissible mixed-use activities shall be counted towards FAR.

(iv) Basement(s) may be permitted up to the setback line free of FAR only up to maximum equivalent of the parking and services requirement with prior approval of the concerned agencies/statutory bodies. Services may include air conditioning plant and equipment, water storage, boiler, electric sub-station HT and LT Panel rooms, transformer compartment, control room, pump house, generator room and other mechanical services, installation of electrical and firefighting equipment, and other services required for the maintenance of the building.

(v) Basement(s) beyond building line shall be kept flushed with the ground and shall be ventilated with mechanical means of ventilation.

(vi) Basement(s) shall be designed to take full load of the fire tender, wherever required and subject to adequate safety measures.

(vii) The ESS, firefighting installations and underground water tank shall neither be counted in ground coverage nor in FAR.

13.2 Norms for Data Centre

Data centre shall be permitted in Industrial, Commercial and PSP use zone with following norms: