

Technical Methodology, Architecture & Use-Case Document

Engineering Specification of the Deterministic 6-Tier Pipeline, Continuous Feature Space, and Dynamic Physics

Architecture: **6-Tier Physics-Grounded Causal Bayesian Hierarchy**

Evaluation Scope: **60,480 Physical Readings (28 AWS Stations / 7 Clusters)**

Verification Status: **67 / 67 Tests Passing (100% Green)**

1. Executive Summary & Problem Formulation

This engineering specification details the system architecture and mathematical implementation of **SkyGuard AI**, grounded directly in [RESEARCH_REPORT.md](#). The platform performs real-time Quality Assurance (QA) and anomaly detection across surface Automatic Weather Station (AWS) networks. Unattended field telemetry stations suffer from a spectrum of physical degradation modes:

- Electrical & Hardware Rail Shortages:** Broken sensor wires or analog-to-digital converter (ADC) ground faults pulling readings to zero or rail limits.
- Telemetry Dropouts:** GSM/LoRa transmission outages causing missing records (NaN values).
- Electrostatic & Inductive Spikes:** Voltage transients, lightning strikes, or digital bit-flips causing extreme single-point excursions.
- Transducer Freezing / Sticking:** Mechanical sensor lockup or ADC multiplexer latch-up where the output stops tracking natural atmospheric variance.
- Slow Calibration Drift:** Electrochemical degradation or optical fouling causing progressive zero-point decalibration (+0.05 to +0.30°C/hr).
- Psychrometric Cross-Channel Breakdown:** Radiation shield overheating or transducer cross-talk violating thermodynamic conservation laws.

Conventional anomaly detection methods fail in field deployments because they either trigger massive false alarms during legitimate dynamic weather events (thunderstorm cold-pool outflows, drylines, diurnal heating) or fail to detect low-amplitude calibration drift. SkyGuard AI resolves this fundamental trade-off through a **6-Tier Physics-Grounded Causal Bayesian Architecture** that blends dynamic diurnal expectations, spatial peer consensus, sequential Wald-Page SPRT hypothesis testing, and thermodynamic physical invariants.


2. End-to-End System Architecture

The processing lifecycle enforces strict modularity between ingestion, temporal alignment, feature generation, hierarchical detection, explainability attribution, and causal state maintenance:

SKYGUARD AI

Intelligent Real-Time AWS Anomaly Detection

Live AWS telemetry Replay / benchmark Core processing Decision engine Health / recovery



eraser

Figure 1: SkyGuard AI End-to-End Modular System Architecture. Sequential progression from raw multi-channel telemetry ingestion through temporal alignment, 49-feature extraction, Tier 0–5 priority arbitration, SHAP attribution, and causal state buffer management.

3. Dynamic-Adaptive Physics & Mathematical Formulation

SkyGuard AI is governed by dynamic data-adaptive computation and minimal physical constants. Every decision threshold adapts continuously in real time based on environmental state.

3.1 Dynamic Diurnal Expectation μ_t

$$\mu_t = f(\theta_{\text{solar}}(t), \text{DoY}) + \text{EWMA}_{\alpha}(\mathbf{x}_{\text{clean}}) + \Delta_{\text{peer-offset}} \quad (\text{Equation 1})$$

Solar Zenith Angle Formulation: $\theta_{\text{solar}}(t) = \arcsin(\sin \varphi \sin \delta + \cos \varphi \cos \delta \cos \omega)$

Where φ is station latitude, δ is solar declination, and ω is solar hour angle. Grounding to continuous solar angles enables cold-start alignment on Tick 0 without requiring historical baseline files.

3.2 Heteroskedastic Dynamic Uncertainty Budget σ_t^2

$$\sigma_t^2 = \sigma_{\text{sensor}}^2 + \sigma_{\text{diurnal}}^2(t) + \sigma_{\text{spatial}}^2(t) + \kappa \cdot \Delta t \quad (\text{Equation 2})$$

Noise Floor Components: σ_{sensor} specifies transducer physical quantization ($\pm 0.10^\circ\text{C}$ for Pt100 RTD, ± 1.0 hPa for station pressure, $\pm 1.0\%$ for RH). $\sigma_{\text{diurnal}}(t)$ is solar radiation intensity modulated (peaks midday, narrows at night). $\sigma_{\text{spatial}}(t)$ tracks live Median Absolute Deviation (MAD) among sibling cluster stations. $\kappa \cdot \Delta t$ represents causal variance diffusion across missing telemetry gaps.

3.3 Sequential Wald-Page SPRT for Low-SNR Calibration Drift

$$LLR_t = \max(0, LLR_{t-1} + |\mu_1 - \mu_0|/\sigma_t \cdot (|\varepsilon_t| - |\mu_1 - \mu_0| / (2\sigma_t)))$$

(Equation 3)

Wald Decision Boundaries: Threshold $A = \ln((1 - \beta) / \alpha) = 6.16$ (with false alarm risk $\alpha = 0.002$, missed risk $\beta = 0.05$). Standardized residuals $\varepsilon_t = (x_t - \mu_t) / \sigma_t$ accumulate sequential evidence over time, catching low-amplitude sensor calibration decay (+0.05 to +0.30°C/hr) without false alarms during normal diurnal shifts.

3.4 3D Thermodynamic Psychrometric Covariance

$$D_{\Sigma}^2 = \mathbf{z}_t^T \Sigma^{-1} \mathbf{z}_t \sim \chi_3^2$$

(Equation 4)

Magnus-Tetens Dewpoint Boundary: $\gamma(T, RH) = (17.67 T)/(243.5 + T) + \ln(RH/100)$, $T_{dew} = (243.5 \gamma)/(17.67 - \gamma)$
Physical Invariant: $T_{dew} \leq T_{dry-bulb} + 1.5^{\circ}\text{C}$. Any reading violating this physical limit represents transducer failure rather than atmospheric reality.


4. Parameter Inventory: Dynamic Quantities vs Physical Invariants

SkyGuard AI eliminates arbitrary heuristic magic numbers. Every parameter is strictly categorized into either a dynamic computed quantity or an unalterable physical specification:

Dynamic Computed Quantities	Physical Transducer Specifications & Invariants
• Diurnal Expectation $\mu(t)$ (Solar Elevation θ_{solar} + EWMA)	• Pt100 RTD Sensor Quantization Floor: $\pm 0.10^{\circ}\text{C}$
• Total Uncertainty Budget $\sigma_{tot}^2(t)$	• Station Barometer Quantization Floor: $\pm 1.0 \text{ hPa}$
• Spatial Peer Consensus Median (Cluster Breakdown Point 50%)	• RH Hygrometer Quantization Floor: $\pm 1.0\%$
• Sibling Peer Dispersion (MAD / IQR)	• Hardware Ground Rail Floor: $-40^{\circ}\text{C} / 0.0 \text{ hPa} / 0.0\% \text{ RH}$
• SPRT Log-Likelihood Ratio Accumulator (LLR_t)	• Wald False Alarm Risk Limit: $\alpha = 0.002$
• 3D Mahalanobis Distance (D_{Σ}^2)	• Wald Missed Detection Risk Limit: $\beta = 0.05$
• Magnus-Tetens Saturation Vapor Pressure $e_s(T)$	• Post-Fault Clean Recovery Horizon: 15 steps
• Continuous Sensor Health Index H_t (0 to 100)	• Maximum Spatial Consensus Peer Distance: 50 km


5. Spatial Topology & Cluster Peer Isolation

To eliminate cross-regional train/serve mismatch and prevent microclimatic contamination (e.g., coastal marine boundaries vs. arid interior plains), SkyGuard structures the observation network into 7 discrete geographic clusters:



4. 49-Dimensional Continuous Physical-Time Feature Architecture


The feature engineering engine (model/features.py) strictly avoids positional row shifts (.shift(n)), utilizing exact physical timestamps and pd.merge_asof to compute continuous derivatives regardless of irregular sampling or dropped packets:



Feature Range	Category	Mathematical Formulation	Diagnostic Purpose
01 – 03	Raw Telemetry Channels	$x_t = [T_t, P_t, RH_t]$	Base atmospheric observation state.
04 – 06	Innovation Residuals	$z_t = (x_t - \mu_{diurnal}) / \sigma_{diurnal}$	Normalized deviation from local expectation.
07 – 12	Rate-of-Change Velocities	$\Delta x / \Delta t = (x_t - x_{t-\Delta t}) / \Delta t_{hours} \text{ (1h, 3h)}$	Captures sudden atmospheric jumps vs. spikes.
13 – 15	Short-Term Volatility	$\sigma_{3h}(x) = [(1/N) \sum (x_i - \bar{x})^2]^{0.5}$	Identifies turbulence vs. abnormal stillness.
16 – 17	Psychrometric Couplings	$T_{dew} = T - (100 - RH) / 5$; $VPD = e_s(T)(1 - RH / 100)$	Clausius-Clapeyron thermodynamic consistency.
18 – 21	Cyclical Time Encodings	$\sin / \cos(2\pi \cdot \text{Hour} / 24), \sin / \cos(2\pi \cdot \text{DOY} / 365)$	Diurnal and seasonal cyclical phase alignment.
22	Elapsed Physical Interval	$\Delta t_{hours} = (t_k - t_{k-1}) / 3600.0$	Exact physical elapsed time tracking.
23 – 25	Robust Statistical Scales	$Scale_{robust} = (x_t - median) / IQR$	Outlier-resistant localized baseline scaling.
26 – 28	Sensor Gap Tracking	$\Delta t_{valid} = \text{Hours since last trusted observation}$	Tracks quarantined sensor downtime duration.
29 – 46	Rolling Ranges & Slopes	$Range_W = \max_W(x) - \min_W(x)$; $Slope_W = Cov(t, x) / Var(t)$	Multi-scale dispersion (1,3,6,24h) & synoptic trend.
47 – 49	Diurnal Residual Baselines	$r_{diurnal} = x_t - \text{Baseline}(h_{diurnal})$	Hour-of-day baseline residual tracking.

5. Deterministic Tier 0–5 Priority Hierarchy


DecisionEngine.decide (model/detect.py) executes a strict top-down priority arbitration cascade where deterministic physical laws always take precedence over statistical models:



- **TIER 0 (Hard Invariants & Rails):** Evaluates electrical ground faults (0.00V) and absolute physical bounds (T $\notin$ [-40, +60°C], P $\notin$ [800, 1100 hPa], RH $\notin$ [0, 100%]). Breaches immediately return FAULT (CRITICAL) and bypass all downstream computation.
- **TIER 1 (Specialist Jump & Frozen LLR):** Evaluates instantaneous dynamic acceleration (>5.0 σ jump LLR) and F-ratio variance collapse over contiguous 4-hour windows.
- **TIER 2 (Persistent SPRT Drift):** Executes Sequential Probability Ratio Test on standardized innovation residuals to accumulate low-SNR calibration drift (+0.05°C/hr) over time.
- **TIER 3 (Cross-Channel 3D Mahalanobis Covariance):** Evaluates joint 3D covariance distance D^2 . If $D^2 > 16.27$ ($p < 10^{-3}$), flags multivariate thermodynamic breakdowns.
- **TIER 4 (Model-Dominant Isolation Forest):** Evaluates the 49-feature continuous matrix through an ensemble of 100 Isolation Trees, isolating complex unstructured anomalies.
- **TIER 5 (Spatial Consensus Veto & Arbiter):** If an anomaly flag is raised by Tiers 1–4, the spatial consensus engine inspects the 3 sibling stations in the cluster. If ≥ 2 peers exhibit matching directional rate-of-change movement, the anomaly is classified as a genuine regional weather event, and the alert is VETOED to NORMAL.

6. Causal State Management & Sensor Health Lifecycle

To prevent corrupted telemetry from polluting future baseline estimates, StateManager (model/state.py) enforces strict ground-truth isolation:



Causal Ground-Truth Exclusion Rule: When an observation is classified as *FAULT* (or when a sensor is in *OFFLINE* health state), the observation is strictly quarantined. It is recorded in the raw historical audit log but excluded from the internal sliding StationBuffer deque, ensuring that rolling means, variances, and diurnal baselines remain 100% uncontaminated.

7. Operational Use-Case Workflows

SkyGuard's capabilities map directly to concrete meteorological and field operations:

Use Case 1: Automated Real-Time AWS Quality Control		CURRENTLY DEMONSTRATED
Operational Workflow: Continuous real-time screening of raw surface streams (T, P, RH) across 28 national AWS stations.	Validation Status: Validated across 60,480 evaluation rows in authoritative 7-seed benchmark; achieves 95.42% ± 0.36% mean recall, 73.33% ± 1.37% mean precision, and 82.92% ± 0.89% mean F1-score.	
Use Case 2: NWP Data Assimilation Boundary Protection		CURRENTLY DEMONSTRATED
Operational Workflow: Automatic quarantining of spurious sensor spikes and unphysical thermodynamic readings before ingestion into 4D-Var data assimilation grids.	Validation Status: Guaranteed via StationBuffer causal exclusion, preventing bad data from contaminating forecast model initialization.	
Use Case 3: Targeted Field Maintenance & Sensor Health		CURRENTLY SUPPORTED
Operational Workflow: Uses SHAP local feature attributions and fault classification to dispatch technicians to specific degraded sensor modules.	Validation Status: Identifies active hardware failures and sensor health degradation; does not predict future failures prior to onset.	
Use Case 4: Embedded Microcontroller Edge Execution (ESP32 TinyML)		CURRENTLY DEMONSTRATED
Operational Workflow: Running lightweight fixed-point (Q8.8) C++ inference engine directly on ESP32 datalogger firmware (EDGE/esp32/src/edge/edge_engine.cpp) to screen telemetry at the edge before transmission.	Validation Status: Fully operational C++ firmware compiled and verified on 240 MHz dual-core ESP32 CPU with a 26.5 KB PROGMEM Flash footprint, enabling immediate hardware protection and offline blackout resilience.	

8. Current vs. Future Architectural Matrix

Subsystem	Current Implemented Architecture	Demonstrated Status	Future Scope
Inference Engine	Vectorized CPU Engine & ESP32 Q8.8 C++ Firmware	DEMONSTRATED	ARM Cortex-M / RISC-V edge optimization
Temporal State Buffer	In-memory circular deques (collections.deque) & 512-slot MCU SRAM ring buffer	DEMONSTRATED	Distributed Redis state cache
Storage Layer	Flat-file CSV streaming & SQLite / TimescaleDB store	DEMONSTRATED	Multi-region distributed PostgreSQL cluster
Spatial Discovery	Static 7-cluster topology (4 stations/cluster)	DEMONSTRATED	Dynamic PostGIS radius queries
API & Streaming	FastAPI REST endpoints + WebSockets + USB Serial Bridge	DEMONSTRATED	MQTT / gRPC streaming gateway

9. References

- **[M01]** Liu, F. T., Ting, K. M., and Zhou, Z.-H. "Isolation Forest." IEEE ICDM, 2008.
- **[M02]** Page, E. S. "Continuous Inspection Schemes." Biometrika, vol. 41, 1954, pp. 100–115.
- **[M03]** Lundberg, S. M., and Lee, S.-I. "A Unified Approach to Interpreting Model Predictions." NeurIPS, 2017.
- **[M05]** Mahalanobis, P. C. "On the generalised distance in statistics." Proc. Natl. Inst. Sci. India, 1936.