

INSPECTION REPORT INSP-E201-2023-08-01

Inspection Report: INSP-E201-2023-08-01

Equipment / Location: E-201 Date: 2023-08-01

Method: thermal performance survey Result: ALERT

DETAILS:

E-201 CW-side approach temperature 7.5 degC above clean baseline. Fouling significant; correlates with P-101 high-temperature trip risk on TI-1103. Backflush/chemical clean recommended.

Inspector: N. Kaur (Inspection Engineer)