

INSPECTION REPORT INSP-EARTH-2026-02-18

Inspection Report: INSP-EARTH-2026-02-18

Equipment / Location: T-301 Date: 2026-02-18

Method: tank earthing resistance test (megger, competent person) Result: PASS

DETAILS:

Annual earth-resistance test per Petroleum Rules 2002 Rules 127/128: T-301 measured 2.1 ohms and T-302 measured 2.4 ohms across both diametrically opposite connections (limit 7 ohms). Both tanks retain two separate and distinct earth connections. Record retained in the licensee file.

Inspector: N. Kaur (Inspection Engineer)