

# INSPECTION REPORT INSP-FIREDRILL-2025-01-15

Inspection Report: INSP-FIREDRILL-2025-01-15

Equipment / Location: Area 3      Date: 2025-01-15

Method: emergency response drill record      Result: PASS

## DETAILS:

Fire and emergency drill conducted for Area 3 tank farm (T-301/T-302 scenario). Muster time 6 min. NOTE: Factories Act read with State Rules and OISD guidance expects drills at least once every calendar quarter for MAH units. No later drill record exists for Area 3 as of mid-2026.

Inspector: N. Kaur (Inspection Engineer)