

INSPECTION REPORT INSP-FWSPRAY-2026-03-02

Inspection Report: INSP-FWSPRAY-2026-03-02

Equipment / Location: T-302 Date: 2026-03-02

Method: fixed water spray system quarterly function test Result: PASS

DETAILS:

Fixed water spray (deluge) system installed on T-302 (naphtha, Class A, diameter > 6 m per OISD-STD-116 cl. 4.2.1) function-tested: deluge valve opened on test signal, ring main pressure adequate, nozzles clear. Quarterly test record current.

Inspector: N. Kaur (Inspection Engineer)