

INSPECTION REPORT INSP-PSV1101-2022-04-12

Inspection Report: INSP-PSV1101-2022-04-12

Equipment / Location: PSV-1101 Date: 2022-04-12

Method: bench pop test Result: PASS

DETAILS:

PSV-1101 bench tested and recertified (see WO-2022-0410). Certificate PSV-CERT-2231. Next test due within the OISD-STD-132 periodicity for critical relief valves.

Inspector: N. Kaur (Inspection Engineer)