

INSPECTION REPORT INSP-STR101-2022-03-14

Inspection Report: INSP-STR101-2022-03-14

Equipment / Location: STR-101 Date: 2022-03-14

Method: dP gauge reading Result: PASS

DETAILS:

STR-101 differential pressure recorded 0.15 bar (normal < 0.3, clean ~0.1). Within normal range.

Inspector: N. Kaur (Inspection Engineer)