

INSPECTION REPORT INSP-STR101-2025-02-10

Inspection Report: INSP-STR101-2025-02-10

Equipment / Location: STR-101 Date: 2025-02-10

Method: dP gauge reading Result: PASS

DETAILS:

STR-101 differential pressure recorded 0.14 bar (normal < 0.3, clean ~0.1). Within normal range.

Inspector: N. Kaur (Inspection Engineer)