

INSPECTION REPORT INSP-T301-2021-11-20

Inspection Report: INSP-T301-2021-11-20

Equipment / Location: T-301 Date: 2021-11-20

Method: external visual + UT thickness (OISD-129 schedule) Result: PASS

DETAILS:

T-301 external inspection completed. Shell courses UT within corrosion allowance. Per OISD-STD-129 external inspection interval (5 years), next external inspection due by 2026-11-20.

Inspector: N. Kaur (Inspection Engineer)