

INSPECTION REPORT INSP-TANKMOUNT-2025-10-12

Inspection Report: INSP-TANKMOUNT-2025-10-12

Equipment / Location: T-302 Date: 2025-10-12

Method: post-monsoon tank mountings check (OISD-129 10.1.3) Result: PASS

DETAILS:

Post-monsoon annual check of tank mountings for T-301 and T-302: breather valves, P&V valves and flame arrestors removed, cleaned and function-tested operable. PSV-3101 visually verified in-service. Completed within the 2025 post-monsoon window.

Inspector: N. Kaur (Inspection Engineer)