

INSPECTION REPORT INSP-V205-HYDRO-2023-03-22

Inspection Report: INSP-V205-HYDRO-2023-03-22

Equipment / Location: V-205 Date: 2023-03-22

Method: pressure vessel hydraulic test + internal inspection (SMPV(U) R.19) Result: PASS

DETAILS:

V-205 KO drum hydraulically tested by competent person at the pressure marked on the vessel per SMPV(U) Rules 2016 Rule 19(1)(a); internal inspection and residual thickness measurement completed - thickness within corrosion allowance. Test certificate CP/2023/0187. Next periodic test due 2028-03-22.

Inspector: N. Kaur (Inspection Engineer)