

## BurgFlow MS-40D IOM - Section 4: Cartridge Seal Installation

DOC CONTROL

UNIT-4 LIBRARY

### SECTION 4 - MECHANICAL SEAL (CARTRIDGE) INSTALLATION

- 4.1 Handle cartridge by the gland plate only. Do not compress the setting clips before the sleeve collar is torqued.
- 4.2 Torque gland bolts to 25 Nm in a star pattern.
- 4.3 Connect API Plan 11 flush from discharge tapping through the  $\varnothing.125$  in orifice to the seal chamber port marked F.
- 4.4 Remove setting clips AFTER final alignment. Rotate shaft by hand; torque shall not exceed 12 Nm.
- 4.5 On commissioning, vent the seal chamber until liquid emerges. Dry running for more than 30 seconds voids warranty.