

PERMIT TO WORK PTW-2019-0288

Permit to Work: PTW-2019-0288 Type: Confined Space Entry

Date: 2019-08-24 Equipment: TK-401 Area: Area 4

Entry for desludging. Purge started 06:10, entry 08:25. Gas test 07:55: O2 20.8%, H2S 2 ppm, LEL 0%. See NM-2019-07.

Precautions per SOP-ET-005 / SOP-HW-001 as applicable.