

SOP-CT-006 REV 1: CT-101 Cooling Tower Basin Cleaning & Dosing

Standard Operating Procedure SOP-CT-006 Revision: 1 Effective date: 2019-08-30
Title: CT-101 Cooling Tower Basin Cleaning & Dosing

PROCEDURE STEPS:

1. Reduce CW demand; swing to single-pump operation.
2. Vacuum basin silt quadrant by quadrant (monsoon: monthly; dry season: quarterly).
3. Verify biocide and dispersant dosing rates.
4. Record basin turbidity sample result.

HAZARDS: Legionella aerosol; slippery surfaces.

Approved by: Plant Manager, Unit 4