

SOP-EX-003 REV 1: E-201 Exchanger Backflush / Chemical Cleaning

Standard Operating Procedure SOP-EX-003 Revision: 1 Effective date: 2018-04-22

Title: E-201 Exchanger Backflush / Chemical Cleaning

PROCEDURE STEPS:

1. Swap CW duty to P-102 leg / E-202 trim as applicable.
2. Isolate E-201 CW side; connect backflush hoses.
3. Backflush against normal flow for 2 h; monitor effluent clarity.
4. If approach temperature not restored, circulate approved descalant 4 h.
5. Neutralize, drain to ETP via TK-401, restore lineup.

HAZARDS: Chemical handling; pressurized hoses.

Approved by: Plant Manager, Unit 4