

SOP-PSV-002 REV 1: PSV Removal, Bench Testing and Reinstallation

Standard Operating Procedure SOP-PSV-002 Revision: 1 Effective date: 2017-05-16

Title: PSV Removal, Bench Testing and Reinstallation

PROCEDURE STEPS:

1. Confirm equipment depressurized and isolated.
2. Remove PSV; tag with location and set pressure.
3. Bench pop test at certified shop; witness by Inspection.
4. Recertify, fit new gaskets, reinstall, seal wire.
5. Update test register and certificate file (OISD-STD-132 periodicity).

HAZARDS: Trapped pressure; lifting.

Approved by: Plant Manager, Unit 4