

WORK ORDER WO-2019-1004

Work Order No: WO-2019-1004 Type: PM Priority: P3
Equipment: E-202 Date completed: 2019-01-01
Title: Trim cooler dP survey

FINDINGS / WORK PERFORMED:

Shell-side dP 8 bar. No action.

Parts used: consumables

Labor hours: 3 Equipment downtime: 0 h

Raised by: A. Deshpande (Maintenance Planner)

Closed by: S. Venkatesan (Shift Supervisor)

Reference drawing: D-CW-104 rev 3