

WORK ORDER WO-2019-1006

Work Order No: WO-2019-1006 Type: PM Priority: P3

Equipment: T-302 Date completed: 2019-09-07

Title: Tank dyke and valve inspection

FINDINGS / WORK PERFORMED:

Dyke wall sound, drain valve locked closed.

Parts used: consumables

Labor hours: 6 Equipment downtime: 0 h

Raised by: A. Deshpande (Maintenance Planner)

Closed by: S. Venkatesan (Shift Supervisor)