

WORK ORDER WO-2020-1012

Work Order No: WO-2020-1012 Type: PM Priority: P3
Equipment: E-202 Date completed: 2020-06-20
Title: Trim cooler dP survey

FINDINGS / WORK PERFORMED:

Shell-side dP 20 bar. No action.

Parts used: consumables

Labor hours: 2 Equipment downtime: 0 h

Raised by: A. Deshpande (Maintenance Planner)

Closed by: S. Venkatesan (Shift Supervisor)

Reference drawing: D-CW-104 rev 3