

WORK ORDER WO-2020-1014

Work Order No: WO-2020-1014 Type: PM Priority: P3

Equipment: T-302 Date completed: 2020-11-20

Title: Tank dyke and valve inspection

FINDINGS / WORK PERFORMED:

Dyke wall sound, drain valve locked closed.

Parts used: consumables

Labor hours: 4 Equipment downtime: 0 h

Raised by: A. Deshpande (Maintenance Planner)

Closed by: S. Venkatesan (Shift Supervisor)