

WORK ORDER WO-2021-1024

Work Order No: WO-2021-1024 Type: PM Priority: P3

Equipment: P-107 Date completed: 2021-07-09

Title: Effluent pump coupling alignment check

FINDINGS / WORK PERFORMED:

Alignment within 0.05 mm TIR.

Parts used: consumables

Labor hours: 3 Equipment downtime: 0 h

Raised by: A. Deshpande (Maintenance Planner)

Closed by: S. Venkatesan (Shift Supervisor)

Reference drawing: D-ET-401 rev 1