

WORK ORDER WO-2022-0410

Work Order No: WO-2022-0410 Type: PM Priority: P3

Equipment: PSV-1101 Date completed: 2022-04-12

Title: PSV-1101 removal, bench test and recertification

FINDINGS / WORK PERFORMED:

Pop test at 1.02x set pressure - PASS. Recertified and reinstalled. Next test due per OISD-STD-132 interval.

Parts used: gaskets

Labor hours: 6 Equipment downtime: 0 h

Raised by: N. Kaur (Inspection Engineer)

Closed by: N. Kaur (Inspection Engineer)

Reference drawing: D-CW-104 rev 3