

WORK ORDER WO-2022-1026

Work Order No: WO-2022-1026 Type: PM Priority: P3

Equipment: CT-101 Date completed: 2022-07-21

Title: Cooling tower basin inspection and dosing check

FINDINGS / WORK PERFORMED:

Basin silt level 35mm. Biocide dosing pump OK.

Parts used: consumables

Labor hours: 3 Equipment downtime: 0 h

Raised by: A. Deshpande (Maintenance Planner)

Closed by: S. Venkatesan (Shift Supervisor)

Reference drawing: D-CW-104 rev 3