

WORK ORDER WO-2023-1035

Work Order No: WO-2023-1035 Type: PM Priority: P3
Equipment: MOV-110 Date completed: 2023-08-17
Title: MOV partial stroke test

FINDINGS / WORK PERFORMED:

Stroke time 20s, within spec. Torque profile normal.

Parts used: consumables

Labor hours: 6 Equipment downtime: 0 h

Raised by: A. Deshpande (Maintenance Planner)

Closed by: S. Venkatesan (Shift Supervisor)

Reference drawing: D-CW-104 rev 3