

WORK ORDER WO-2024-1043

Work Order No: WO-2024-1043 Type: PM Priority: P3
Equipment: MOV-110 Date completed: 2024-10-11
Title: MOV partial stroke test

FINDINGS / WORK PERFORMED:

Stroke time 35s, within spec. Torque profile normal.

Parts used: consumables

Labor hours: 2 Equipment downtime: 0 h

Raised by: A. Deshpande (Maintenance Planner)

Closed by: S. Venkatesan (Shift Supervisor)

Reference drawing: D-CW-104 rev 3