

WORK ORDER WO-2024-1048

Work Order No: WO-2024-1048 Type: PM Priority: P3
Equipment: P-107 Date completed: 2024-09-06
Title: Effluent pump coupling alignment check

FINDINGS / WORK PERFORMED:
Alignment within 0.05 mm TIR.

Parts used: consumables
Labor hours: 6 Equipment downtime: 0 h
Raised by: A. Deshpande (Maintenance Planner)
Closed by: S. Venkatesan (Shift Supervisor)
Reference drawing: D-ET-401 rev 1