

WORK ORDER WO-2025-0301

Work Order No: WO-2025-0301 Type: PM Priority: P3

Equipment: PSV-3101 Date completed: 2025-03-06

Title: PSV-3101 bench test and recertification

FINDINGS / WORK PERFORMED:

Pop test PASS at set pressure. Recertified. In compliance window.

Parts used: gaskets

Labor hours: 5 Equipment downtime: 0 h

Raised by: N. Kaur (Inspection Engineer)

Closed by: N. Kaur (Inspection Engineer)