

WORK ORDER WO-2025-1054

Work Order No: WO-2025-1054 Type: PM Priority: P3

Equipment: T-302 Date completed: 2025-04-19

Title: Tank dyke and valve inspection

FINDINGS / WORK PERFORMED:

Dyke wall sound, drain valve locked closed.

Parts used: consumables

Labor hours: 2 Equipment downtime: 0 h

Raised by: A. Deshpande (Maintenance Planner)

Closed by: S. Venkatesan (Shift Supervisor)